

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Kearny County	Fraction 1/4 1/4 NW 1/4	Section number 27	Township number T 26 S	Range number R 36 E/W
2. Distance and direction from nearest town or city: 12 South of Lakin, 6 1/2 East, 1/2 South			3. Owner of well: Earl Berlier R.R. or street: Lakin, KS 67860 City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 6. Bore hole dia. 26 in. Completion date 7-15-79 Well depth 380 ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 380 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
5. Type and color of material			From	To	10. Screen: Manufacturer's name Johnson Type Johnson Galv. D100-16" Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/2 to 5/8
Casing Schedule 0 - 150 Plain 150 - 335 Perf. 335 - 375 Screen 375 - 380 Perf.					11. Static water level: 183 ft. below land surface Date 5-7-79
					12. Pumping level below land surfaces: 190 ft. after 2 hrs. pumping 1200 g.p.m. 192 ft. after 4 hrs. pumping 1550 g.p.m. Estimated maximum yield 1550 g.p.m.
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. inches above grade
					15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Could 5 Stg. 12" Bowl Model number <input type="checkbox"/> HP 125 Volts <input type="checkbox"/> Length of drop pipe 240 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation: Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling Co. 208 Business name License No. <input type="checkbox"/> Address Box A, Garden City, KS 67846 Signed Robert D. Minter Date 8/17/79 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8260 • P.O. Box A • GARDEN CITY, KANSAS 67846

April 12, 1979

Earl Berlier
Kearny County

Location: NW $\frac{1}{4}$ 27-26-36 Pivot
Static Water Level -
Test #2

0	35	Sand
35	95	Brown Clay
95	170	Med. to coarse gravel (loose)
170	183	Med. to coarse gravel 30% Clay (loose)
183	263	Fine to med. sand & gravel streaks of coarse gravel (loose)
263	282	Brown Sandy Clay streaks of gravel 30% (loose)
282	377	Fine to med. sand & gravel (loose) streaks of coarse gravel
377	386	Brown & gray Clay with Brown Rock (tight) (hard streaks)
386	395	Brown Gray & Yellow Clay with Brown Rock (hard)