


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <b>Kearny County</b>	Fraction <b>1/4 1/4 NW 1/4</b>	Section number <b>29</b>	Township number <b>T 26 S</b>	Range number <b>R 36 E/W</b>
2. Distance and direction from nearest town or city: <b>1 1/2 South of Lakin, 4 1/2 East, 1/2 South</b> Street address of well location if in city:			3. Owner of well: <b>Earl Berlier</b> R.R. or street: <b>Lakin, KS 67860</b> City, state, zip code:		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. <b>26</b> in. Completion date <b>7-15-79</b> Well depth <b>425</b> ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>1 ft.</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>4 1/2</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>219</b>		
			10. Screen: Manufacturer's name <b>Johnson</b> Type <b>Johnson Galv</b> Dia. <b>100-16"</b> Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> Set between <input type="checkbox"/> ft. and <input type="checkbox"/> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <b>yes</b> Size range of material <b>1/2 to 5/8</b>		
			11. Static water level: <input type="checkbox"/> mo./day/yr. <b>166</b> ft. below land surface Date <b>5-7-79</b>		
(Use a second sheet if needed)			12. Pumping level below land surfaces: <b>172</b> ft. after <b>2</b> hrs. pumping <b>1100</b> g.p.m. <b>175</b> ft. after <b>4</b> hrs. pumping <b>1600</b> g.p.m. Estimated maximum yield <b>1600</b> g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <b>1 ft.</b> inches above grade		
			15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>00</b> ft. to <b>10</b> ft.		
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <b>N/A</b> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
(Use a second sheet if needed)			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Could 5 atg. 12" Bowl</b> Model number <input type="checkbox"/> HP <b>125</b> Volts <input type="checkbox"/> Length of drop pipe <b>240</b> ft. capacity <b>1000</b> p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter Wilson Drilling Co. 208</b> Business name License No. <input type="checkbox"/> Address <b>Box A, Garden City, KS 67846</b> Signed <b>Minter Wilson</b> Date <b>8/17/79</b> Authorized representative		
			18. Elevation:		
			19. Remarks:		
			Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

*The Professionals*

# MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

April 13, 1979

Earl Berlier  
Kearny County

Location: NW $\frac{1}{4}$  29-26-36 Pivot  
Static Water Level -  
Test #

0	30	Sand
30	76	Brown Clay
76	137	Med. to coarse gravel (loose)
137	149	Brown Clay
149	155	Fine to med. sand and gravel (loose)
155	160	Brown Clay
160	192	Fine to med. sand and gravel (loose)
192	335	Fine to med. sand and gravel streaks of coarse gravel (loose)
335	353	Fine to med. sand and gravel streaks of coarse gravel 10% Clay (loose)
353	421	Fine to med. sand & gravel streaks of coarse gravel (loose)
421	433	Brown Gray & Yellow Clay
433	440	Yellow Clay & Shale (hard)