


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Location of well:	County Kearny County	Fraction 1/4 1/4 SE 1/4	Section number 32	Ship number 26	Range number 36	E/W
2. Distance and direction from nearest town or city: 14 South of Lakin on Hiway 25, 4 3/4 East, 1/2 North Street address of well location if in city:		3. Owner of well: Tate - Lyle (KI) R.R. or street: 1/2 Brad Tate City, state, zip code: Lakin, KS 67860				
4. Locate with "X" in section below: 		Sketch map:		5. Bore hole dia. 26 in. Completion date 12-22-76 Well depth 424 ft.		
5. Type and color of material		From	To	7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 424 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .219		
				10. Screen: Manufacturer's name Johnson Type Johnson Galv. Dia. 100-16" Slot/gauze 0-210 Plain 210-390 Perf. Set between 390-410 Screen 410-424 Perf. Gravel pack? yes Size range of material 1/4 to 5/8		
				11. Static water level: 160 g.p.m. mo./day/yr. Date 12-22-76 Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
				13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. inches above grade		
				15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input checked="" type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name License No. 97846 Address Box A, Garden City, KS Signed Madene Date 12-22-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 278-8267 P.O. Box A GARDEN CITY, KANSAS 67840

December 22, 1976

Tate - Lyle
Kearny County

Location: SE $\frac{1}{4}$ 32-26-36
Static Water Level - 160
Test # Pivot

0	23	Fine Sand
23	35	Brown Clay
35	97	Med. to coarse gravel (loose)
97	140	Brown Clay
140	151	Fine to med. sand and fine gravel (loose)
151	155	Brown Clay
155	168	Fine to med. sand and fine gravel (loose)
168	190	Fine to med. sand and gravel (loose)
190	212	Brown Clay
212	418	Fine to med. sand and gravel (loose)
418	424	Brown & Yellow Clay with Brown Rock (loose)
424	435	Brown & Yellow Clay with Brown Rock (tight) (Hard Streaks)
435	440	Shale (Hard)

T. D. 424