

20,361

Check: ☒ White Copy, ☐ Blue Copy, ☐ Pink Copy

*The
Professionals*

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 620-276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

NAME WALTER FLETCHER - CIRCLE # 1
COUNTY KEARNY
DATE 12-20-12

LOCATION: N 1/2 4-26-36 - 100 FT. SOUTHEAST OF PIVOT

STATIC WATER LEVEL - APPROX. 210 FT.

TEST # 1

0' TO 1' - TOP SOIL
1' TO 15' - BROWN SANDY CLAY
15' TO 149' - FINE TO MEDIUM SAND & GRAVEL - SOME COARSE
149' TO 158' - BROWN & BLUE CLAY
158' TO 178' - BLUE CLAY
178' TO 196' - BROWN CLAY
196' TO 204' - BROWN CLAY WITH GRAVEL STREAK
204' TO 214' - BROWN CLAY
214' TO 231' - FINE TO MEDIUM SAND & GRAVEL
231' TO 260' - BROWN CLAY WITH GRAVEL STREAKS
260' TO 295' - BROWN CLAY
295' TO 300' - FINE TO MEDIUM SAND & GRAVEL
300' TO 344' - BROWN CLAY
344' TO 384' - FINE TO MEDIUM SAND & GRAVEL
384' TO 404' - BROWN CLAY
404' TO 412' - BROWN CLAY WITH 30% BROWN ROCK
412' TO 422' - BROWN ROCK - 30% BROWN CLAY
422' TO 429' - YELLOW CLAY
429' TO 455' - SHALE - 250-300 PULL DOWN - HARD