

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: Kearny		Fraction NW 1/4 NW 1/4 NE 1/4		Section number 32		Township number T 26		Range number S R 37 E/W																									
2. Distance and direction from nearest town or city: 12 miles South of Lakin on HIWAY 25 = Street address of well location if in city: 1 1/2 mi W of HiWay					3. Owner of well: Carl Waechter R.R. or street: Rfd. #3 City, state, zip code: Ulysses, Kansas 67880																												
4. Locate with "X" in section below: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p>Sketch map:</p> </div> <div> <p>75 ft. South of Windmill</p> </div> </div>					6. Bore hole dia. 7 3/4 in. Completion date 12-9-75 Well depth 210 ft.																												
5. Type and color of material <table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th></th> <th>From</th> <th>To</th> </tr> </thead> <tbody> <tr> <td>sandy clay</td> <td>0</td> <td>20</td> </tr> <tr> <td>sand</td> <td>20</td> <td>40</td> </tr> <tr> <td>*** sand, gyp</td> <td>40</td> <td>60</td> </tr> <tr> <td>gyp</td> <td>60</td> <td>80</td> </tr> <tr> <td>clay, few sand streaks</td> <td>80</td> <td>180</td> </tr> <tr> <td>fine sand</td> <td>180</td> <td>200</td> </tr> <tr> <td>**** Med. sand</td> <td>200</td> <td>210</td> </tr> </tbody> </table>						From	To	sandy clay	0	20	sand	20	40	*** sand, gyp	40	60	gyp	60	80	clay, few sand streaks	80	180	fine sand	180	200	**** Med. sand	200	210	7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
						From	To																										
					sandy clay	0	20																										
					sand	20	40																										
*** sand, gyp	40	60																															
gyp	60	80																															
clay, few sand streaks	80	180																															
fine sand	180	200																															
**** Med. sand	200	210																															
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																																	
9. Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded glu Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 320 lbs./ft. Dia. 5 in. to 202 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. Sch 40																																	
10. Screen: Manufacturer's name Jess-Lowell Type plastic Dia. 5 inches Slot/gauze 1/16 Length 1 1/2 Set between 182 ft. and 202 ft. Gravel pack? yes Size range of material 1/8																																	
11. Static water level: 72 ft. below land surface Date 12/9/75																																	
12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 20 g.p.m.																																	
13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____																																	
14. Well head completion: _____ Pitless adapter <input checked="" type="checkbox"/> Inches above grade																																	
15. Well grouted? no With: _____ Neat cement _____ Bentonite _____ Concrete Depth: From _____ ft. to _____ ft.																																	
16. Nearest source of possible contamination: NA ft. _____ Direction _____ Type _____ Well disinfected upon completion? _____ Yes _____ No																																	
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																	
18. Elevation: drainage good Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley																																	
19. Remarks: Grouting and cement slab to be completed by customer. He knows this to be R. <div style="text-align: right;"> High Plains Drilling & Supply, Inc. 136 102 N 3rd, Garden City, KS 1-476 </div>																																	
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <div style="text-align: right;"> Carl Waechter Carl Waechter </div>																																	

Form WWC-5