

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kearny	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 6	Township number T 26 S	Range number R 38 E/W
2. Distance and direction from nearest town or city: 14 north, 1/2 west 2 1/2 north of four way stop at Ulysses, Ks.		3. Owner of well: Zo-Mar Inc. R.R. or street: % Ora Martin City, state, zip code: RFD #3, Ulysses, Ks. 67880				
4. Locate with "X" in section below: <p>Sketch map: House, Septic tank, 120' to house, 75' to garage, 120' to house, 75' to garage</p>				6. Bore hole dia. 9 1/4 in. Completion date 11/7/78 Well depth 300 ft.		
5. Type and color of material				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Surface				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Very fine sand				9. Casing: Material styrene <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP 5 200 Weight 200 lbs./ft. Dia. 5 in. to 200 ft. depth Wall thickness: inches or Dia. 5 in. to 200 ft. depth gage No. 320		
Fine to coarse sand w/clay breakers				10. Screen: Manufacturer's name Sunflower Type styrene Dia. 5" Slot/gauze 1/16" Length 100' Set between 200 ft. and 300 ft. ft. and 300 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4"		
Sandy clay w/lime shale & fine sand strips				11. Static water level: 170 ft. below land surface Date 11-9-78		
Yellow chalk, lime shells, sandrock & Dakota				12. Pumping level below land surfaces: 190 ft. after 6 hrs. pumping 6 g.p.m. ft. after 6 hrs. pumping 6 g.p.m. Estimated maximum yield 11 g.p.m.		
Blue & gray shale & Dakota hard 5%				13. Water sample submitted: X Yes <input type="checkbox"/> No Date 11-9-78		
" " " " " " 3%				14. Well head completion: 18 inches above grade <input checked="" type="checkbox"/> Pitless adapter <input type="checkbox"/> Pitless adapter		
Blue shale, gray clay, black & white Cheyenne 5%				15. Well grouted? <input checked="" type="checkbox"/> = With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
(Use a second sheet if needed)				16. Nearest source of possible contamination: ft. 120 Direction north Type sewer line Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name _____ License No. _____ Address Box 487, Ulysses, Ks. Signed Moore M. Beard Date 12-29-78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5