

2 WATER WELL OWNER: Jerome Lampe
RR#, St. Address, Box # : Route 1 Box 55
City, State, ZIP Code : Kendal, KS 67857

4 DEPTH OF COMPLETED WELL 500 ft. ELEVATION: _____

Depth(s) Groundwater Encountered 1. 240 ft. 2. _____ ft. 3. _____ ft.

WELL'S STATIC WATER LEVEL 240 ft. below land surface measured on mo/day/yr June 19, 95

Pump test data: Well water was 455 ft. after 72 hours pumping 13 gpm

Est. Yield 18 gpm: Well water was _____ ft. after _____ hours pumping _____ gpm

Bore Hole Diameter 9 1/2 in. to _____ ft. and _____ in. to _____ ft.

WELL WATER TO BE USED AS:

1 Domestic	3 Feedlot	6 Oil field water supply	9 Air conditioning	11 Injection well
2 Irrigation	4 Industrial	7 Dewatering	10 Other (Specify below)	
		7 Lawn and garden only	10 Monitoring well	

Was a chemical/bacteriological sample submitted to Department? Yes _____ No ☒ If yes, mo/day/yr sample was submitted _____

Water Well Disinfected? Yes ☒ No _____

5 TYPE OF BLANK CASING USED:		5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued . X . . . Clamped	
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)	Welded	
2 PVC	4 ABS	7 Fiberglass		Threaded	
Blank casing diameter 0 in. to 320		ft. Dia 5	in. to 340 to 440		ft. Dia in. to ft.
Casing height above land surface 12"		in. weight		lbs./ft. Wall thickness or gauge No. SDR 26	

TYPE OF SCREEN OR PERFORATION MATERIAL:			7 PVC	10 Asbestos-cement
1 Steel	3 Stainless steel	5 Fiberglass	<u>8 RMP (SR)</u>	11 Other (specify)
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS	12 None used (open hole)

SCREEN OR PERFORATION OPENINGS ARE:		5 Gauzed wrapped	8 Saw cut	11 None (open hole)
1 Continuous slot	3 Mill slot	6 Wire wrapped	9 Drilled holes	
2 Louvered shutter	4 Key punched	7 Torch cut	10 Other (specify)	

SCREEN-PERFORATED INTERVALS:		From 320	ft. to 340	ft., From	ft. to	ft.
		From 440	ft. to 500	ft., From	ft. to	ft.
GRAVEL PACK INTERVALS:		From 25	ft. to 55	ft., From 75	ft. to 500	ft.
		From	ft. to	ft., From	ft. to	ft.

6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other

Grout Intervals: From 0 ft. to 25 ft. From 55 ft. to 75 ft. From ft. to ft.

What is the nearest source of possible contamination:

1 Septic tank	4 Lateral lines	7 Pit privy	10 Livestock pens	14 Abandoned water well
2 Sewer lines	5 Cess pool	8 Sewage lagoon	11 Fuel storage	15 Oil well/Gas well
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	12 Fertilizer storage	16 Other (specify below)
			13 Insecticide storage

Direction from well? East

How many feet? 15'

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	32	Top Soil and Sandy Clay	229	246	Shale(gray)10% Sandstone
32	49	Sandy Clay	246	295	Gray Shale
49	53	Sand & Gravel	295	311	Gray Shale & 4' Sandstone
53	65	Cemented Sand(hrd),Lt Clay	311	328	Blue Shale
65	98	Sandy Clay	328	344	Blue Shale & 10% Sandstone 2
98	114	Sand & Clay Streaks	344	410	Blue Shale
114	130	Sand & 2' Clay (med)	410	440	Blue Shale & 4' Sandstone
130	137	Cemented Sand(hard)	440	485	White Clay & 10% Sandstone
137	144	Clay	485	515	Sandstone
144	147	Cemented Sand(hard)	515	520	Blue Shale
147	164	Cemented Sand(hrd), Clay Streaks			
164	180	Shale, Lt. Clay Blue			
180	196	Shale, Lt. Clay(hrd)Blue			
196	213	Shale(hrd)blue			
213	229	Gray Shale			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) June 19, 95 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 473 This Water Well Record was completed on (mo/day/yr) June 20, 95 under the business name of Tyler Water Well Service by (signature) 