


**USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.**

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

County Hamilton		Fraction NW 1/4 NW 1/4 SW 1/4		Section number 20		Township number 26		Range number 41		Elev. (ft.) 1000	
2. Distance and direction from nearest town or city: 14 North, 3 1/2 west, 1/2 south of Hwy Jct. at Johnson, Ks.						3. Owner of well: Charles Collins R.R. or street: Johnson, Kansas 67855 City, state, zip code:					
4. Locate with "X" in section below: 						Sketch map:					
5. Type and color of material						From		To		6. Bore hole dia. 27 in. Completion date 9/28/76 Well depth 478 ft.	
Surface						0		2		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Very fine sand & clay breakers						2		13		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Brown sandy clay						13		42		9. Casing: Material steel Height: Above below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 14 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.8 lbs./ft. Dia. 16 in. to 232.6 ft. depth Wall thickness 1/2 inches or Dia. 16 in. to 232.6 ft. depth Gauge No. 219	
Yellow chalk, gray clay and sandrock & Dakota						42		62		10. Screen: Manufacturer's name Lakewood Pipe of Texas Type steel Dia. 16" Slot/gauze 3/16 Length 245.6' Set between 232.6 ft. and 478 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 5/8"	
Gray clay, bleu shale and Kakota Dakota						62		123		11. Static water level: 137 ft. below land surface Date 8-25-76 mo./day/yr.	
Blue shale and Kakota Dakota						123		257		12. Pumping level below land surfaces: 218 ft. after 12 hrs. pumping 1050 g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1400 g.p.m.	
Blue shale, white clay and Dakota						257		311		13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
White clay and Dakota						311		478		14. Well head completion: NA Pitless adapter _____ inches above grade	
										15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
										16. Nearest source of possible contamination: NA ft. _____ Direction _____ Type _____ Well disinfected upon completion? _____ Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
										17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation:						19. Remarks:					
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drilling Co. 164 Business name Box 487, Ulysses, KS. License No. _____ Address _____ Signed M. Beard Date 10/11/76 Authorized representative					