

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Hamilton	Fraction SW 1/4 SE 1/4 SW 1/4	Section number 34	Township number T 26 S R 41 E/W	Range number
2. Distance and direction from nearest town or city: 11 north, 1 3/4 west of hiway intersection at Johnson, Ks. <small>Street address or well location if in city.</small>			3. Owner of well: Irvin Lewis, Jr. R.R. or street: Star Route City, state, zip code: Syracuse, Ks. 67878			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>27</u> in. Completion date <u>9-4-75</u> Well depth <u>295.6</u> ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material <u>stl</u> Height: <u>(Above)</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.8</u> lbs./ft. Dia. <u>16</u> in. to <u>133.2</u> ft. depth; Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth; gage No. <u>219</u>		
Surface		0	2	10. Screen: Manufacturer's name <u>Lakewood</u> <u>Pipe of Texas</u> Type <u>steel</u> Dia. <u>16"</u> Slot/gauze <u>3/16"</u> Length <u>162.4</u> ft. Set between <u>133.2</u> ft. and <u>295.6</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <u>yes</u> Size range of material <u>1/4 x 5/8</u>		
Sandy clay		2	49	11. Static water level: <u>72</u> ft. below land surface Date <u>9-3-75</u> mo./day/yr.		
Fine to coarse sand		49	76	12. Pumping level below land surfaces: <u>137</u> ft. after <u>5</u> hrs. pumping <u>1450</u> g.p.m. <u>142</u> ft. after <u>7</u> hrs. pumping <u>1500</u> g.p.m. Estimated maximum yield <u>1500</u> g.p.m.		
Brown clay w/small sand strips		76	127	13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>		
Medium to coarse sand w/clay breakers		127	140	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade		
Medium to coarse sand		140	152	15. Well grouted? <input checked="" type="checkbox"/> <u> </u> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Medium to coarse sand w/clay breakers 18 ft		152	176	16. Nearest source of possible contamination: <u>NA</u> ft. <u> </u> Direction <u> </u> Type <u> </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
Sandy clay w/sand strips 1-1-1-1 4 ft		176	219	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Yellow chalk, red & gray clay w/sandstone strips 12 ft		219	260	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Houck Bros. Drlg. Co.</u> <u>164</u> Business name <u>Box 487, Ulysses, Ks.</u> License No. <u> </u> Address <u> </u> Signed <u>M. Beard</u> Date <u>11-24-75</u> Authorized representative		
Yellow chalk w/sandstone strips 17 ft		260	294			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

T
R
E
S
E
C
1/4
1/4
SW
SE
SW