


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Hamilton Grant	Fraction NW 1/4 NW 1/4 SW 1/4	Section number 7	Township number T 26	Range number S R 42
2. Distance and direction from nearest town or city: 15 miles north, 1 1/2 west-1/2 north			3. Owner of well: Duane Lewis R.R. or street: Syracuse, Ks. 67878 City, state, zip code:			
4. Locate with "X" in section below: N W  E S 1 Mile			Sketch map:		6. Bore hole dia. 26 in. Completion date _____ Well depth 397.2 12/4/79	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Surface			0	2	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay			2	25	9. Casing: Material steel Height Above or below Threaded _____ Welded <input checked="" type="checkbox"/> Surface 12 in. RMP _____ PVC _____ Weight 36.8 lbs./ft. Dia. 16 in. to 217 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 219	
Sandy clay			25	60	10. Screen: Manufacturer's name Lakewood Pipe of Texas Type steel Dia. 16" Slot/gauze 3/16" Length 160' Set between 217 ft. and 377 ft. _____ ft. and _____ ft.	
Medium sand			60	85	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4 x 5/8"	
Clay and sandy clay			85	185	11. Static water level: _____ mo./day/yr. 229 ft. below land surface Date 8-11-79	
Clay w/medium sand strips			185	220	12. Pumping level below land surfaces: 325 ft. after 12 hrs. pumping 920 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1000 g.p.m.	
Sandstone (Dakota) medium tight			220	250	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Blue shale & sandstone			250	265	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
Sandstone			265	305	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Clay & shale			305	355	16. Nearest source of possible contamination: ft. _____ Direction _____ Type field Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Sandstone			355	395	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		20.2 feet of Johnson Screen set between 377 and 397.2 feet		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Houck Bros. Drlg. Co. 164 Business name Box 487, Ulysses, Ks. License No. _____ Address _____ Signed Melvin Beard Date 12/4/79 Authorized representative		

276
 420
 W
 Sec 7
 NW 1/4
 NW 1/4
 NW 1/4