


1 LOCATION OF WATER WELL:	Fraction	Section Number	Township Number	Range Number
County: <u>Reno</u>	<u>NE</u> $\frac{1}{4}$ <u>SE</u> $\frac{1}{4}$ <u>SW</u> $\frac{1}{4}$	<u>2</u>	<u>T 26 S</u>	<u>R 7</u> W

Distance and direction from nearest town or city street address of well if located within city?

2 Miles North & 1 1/2 Mile West of Pretty Prairie

2 WATER WELL OWNER:	<u>Rex Blew</u>	Board of Agriculture, Division of Water Resources
RR#, St. Address, Box # :	<u>R.R. 2,</u>	Application Number: <u>38,780</u>
City, State, ZIP Code :	<u>Pretty Prairie, KS 67570</u>	

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	4 DEPTH OF COMPLETED WELL: <u>100</u> ft. ELEVATION:
	Depth(s) Groundwater Encountered 1. <u>44</u> ft. 2. ft. 3. ft.
	WELL'S STATIC WATER LEVEL <u>44</u> ft. below land surface measured on mo/day/yr <u>7-6-94</u>
	Pump test data: Well water was ft. after hours pumping gpm
	Est. Yield <u>800</u> gpm: Well water was ft. after hours pumping gpm
	Bore Hole Diameter <u>30</u> in. to <u>100</u> ft., and in. to ft.
	WELL WATER TO BE USED AS:
	5 Public water supply 8 Air conditioning 11 Injection well
	1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below)
	2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well
	Was a chemical/bacteriological sample submitted to Department? Yes.....No..... <u>X</u>; If yes, mo/day/yr sample was submitted
	Water Well Disinfected? Yes <u>X</u> No

5 TYPE OF BLANK CASING USED:	5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued <u>X</u> Clamped	
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)	Welded
2 PVC	4 ABS	7 Fiberglass		Threaded
Blank casing diameter <u>16</u> in. to <u>59</u> ft., Dia. in. to ft., Dia. in. to ft.				
Casing height above land surface <u>12</u> in., weight <u>16.15</u> lbs./ft. Wall thickness or gauge No. <u>500</u>				
TYPE OF SCREEN OR PERFORATION MATERIAL:	7 PVC	10 Asbestos-cement		
1 Steel	3 Stainless steel	5 Fiberglass	8 RMP (SR)	11 Other (specify)
2 Brass	4 Galvanized steel	6 Concrete tile	9 ABS	12 None used (open hole)
SCREEN OR PERFORATION OPENINGS ARE:	5 Gauzed wrapped	8 Saw cut	11 None (open hole)	
1 Continuous slot	3 Mill slot	6 Wire wrapped	9 Drilled holes	
2 Louvered shutter	4 Key punched	7 Torch cut	10 Other (specify)	
SCREEN-PERFORATED INTERVALS:	From <u>59</u> ft. to <u>99</u> ft., From ft. to ft.			
	From ft. to ft., From ft. to ft.			
GRAVEL PACK INTERVALS:	From <u>20</u> ft. to <u>99</u> ft., From ft. to ft.			
	From ft. to ft., From ft. to ft.			

6 GROUT MATERIAL:	1 Neat cement	2 Cement grout	3 Bentonite	4 Other
Grout Intervals: From <u>0</u> ft. to <u>20</u> ft., From ft. to ft., From ft. to ft.				
What is the nearest source of possible contamination:	10 Livestock pens	14 Abandoned water well		
1 Septic tank	4 Lateral lines	7 Pit privy	11 Fuel storage	15 Oil well/Gas well
2 Sewer lines	5 Cess pool	8 Sewage lagoon	12 Fertilizer storage	16 Other (specify below)
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	13 Insecticide storage	

Direction from well? <u>Southeast</u>	How many feet? <u>300ft</u>				
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	2	Top Soil			
2	9	Clay-Brown			
9	27	Sand-Fine			
27	41	Sand-Small Layers Clay			
41	80	Sand-Medium			
80	83	Clay-Grey			
83	94	Sand-Medium			
94	99	Sand-Fine			
99	100	Shale-Red-Hard			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>7-6-94</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>138</u> This Water Well Record was completed on (mo/day/yr) <u>7-18-94</u> under the business name of <u>Peterson Irrigation Inc.</u> by (signature) <u>Mike Peters</u>
--