

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Reno	Fraction NE 1/4 NW 1/4 NE 1/4	Section number 25	Township number T 26	Range number S R 7 EW						
2. Distance and direction from nearest town or city: 1 mi S, 1/2 W of			3. Owner of well: Vic Albright								
Street address of well location if in city: Pretty Prairie, KS			R.R. or street: AR 1								
			City, state, zip code: Pretty Prairie, KS 67570								
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date 6-24-78							
N S W E				Well depth 39 ft.							
5. Type and color of material		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width:50%;">From</th> <th style="width:50%;">To</th> </tr> </thead> <tbody> <tr> <td>0</td> <td>8</td> </tr> <tr> <td>8</td> <td>43</td> </tr> </tbody> </table>		From	To	0	8	8	43	7. Cable tool ☒ Rotary ☐ Driven ☐ Dug	
				From	To						
				0	8						
				8	43						
				☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary							
8. Use: ☐ Domestic ☐ Public supply ☐ Industry											
☐ Irrigation ☐ Air conditioning ☒ Stock											
☐ Lawn ☐ Oil field water ☐ Other											
		9. Casing: Material Plst Height: Above or below		Threaded ☐ Welded ☐ Surface 14 in.							
		RMP Y PVC ☐ Weight 1.25 lbs./ft.		Dia. 6 in. to 39 ft. depth							
		Dia. 6 in. to 39 ft. depth		Wall Thickness: inches or							
				Dia. 6 in. to 39 ft. depth							
				gauge No. 200							
				10. Screen: Manufacturer's name Sun Flower							
				Type RMP Dia. 6							
				Slot gauge 0.30 Length 10							
				Set between 29 ft. and 39 ft.							
				ft. and 39 ft.							
				Gravel pack? Yes Size range of material F-42							
				11. Static water level: 20 ft. below land surface Date 6-12-78							
				12. Pumping level below land surfaces:							
				24 ft. after 2 hrs. pumping 20 g.p.m.							
				ft. after 2 hrs. pumping 20 g.p.m.							
				Estimated maximum yield 30 g.p.m.							
				13. Water sample submitted: Yes ☒ No ☐ Date 6-12-78							
				14. Well head completion: 14 Inches above grade							
				☐ Pitless adapter ☐ 14 Inches above grade							
				15. Well grouted? Yes							
				With: ☐ Neat cement ☐ Bentonite ☒ Concrete							
				Depth: From 0 ft. to 10 ft.							
				16. Nearest source of possible contamination:							
				ft. 60 Direction E Type Barn lot							
				Well disinfected upon completion? Yes ☒ No ☐							
				17. Pump: ☒ Not installed							
				Manufacturer's name Miller							
				Model number 137 HP 1 Volts 115							
				Length of drop pipe 10 ft. capacity 10 g.p.m.							
				Type:							
				☐ Submersible ☐ Turbine							
				☐ Jet ☐ Reciprocating							
				☐ Centrifugal ☐ Other							
				(Use a second sheet if needed)							
18. Elevation:		19. Remarks:		20. Water well contractor's certification:							
Topography:				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.							
☐ Hill				Miller Water Well 137							
☒ Slope				Business name Miller License No. 137							
☐ Upland				Address Hatchinson, KS							
☐ Valley				Signed Joe Miller 6-24-78 Date							
				Authorized representative							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5