

36-1

1 LOCATION OF WATER WELL: County: Sedgwick		Fraction NW $\frac{1}{4}$ NW $\frac{1}{4}$ NW $\frac{1}{4}$		Section Number 27	Township Number 27 S	Range Number 1 W																																		
Distance and direction from nearest town or city street address of well if located within city? 7125 W. Maple Wichita, Kan																																								
2 WATER WELL OWNER: RR#, St. Address, Box # : 3G Convenience Store City, State, ZIP Code : 7125 West Maple, Wichita, Kansas Board of Agriculture, Division of Water Resources Application Number: _____																																								
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL 25 ft. ELEVATION: _____																																						
		Depth(s) Groundwater Encountered 1. _____ ft. 2. _____ ft. 3. _____ ft. WELL'S STATIC WATER LEVEL _____ ft. below land surface measured on mo/day/yr Pump test data: Well water was _____ ft. after _____ hours pumping _____ gpm Est. Yield _____ gpm; Well water was _____ ft. after _____ hours pumping _____ gpm Bore Hole Diameter 11 7/8" in. to 25 ft. and _____ in. to _____ ft. WELL WATER TO BE USED AS: 5 Public water supply 8 Air conditioning 11 Injection well 1 Domestic 3 Feedlot 6 Oil field water supply 9 Dewatering 12 Other (Specify below) 2 Irrigation 4 Industrial 7 Lawn and garden only 10 Monitoring well mw 36-1 Was a chemical/bacteriological sample submitted to Department? Yes _____ No X _____; If yes, mo/day/yr sample was submitted _____ Water Well Disinfected? Yes _____ No X _____																																						
		5 TYPE OF BLANK CASING USED: 5 Wrought iron 8 Concrete tile CASING JOINTS: Glued _____ Clamped _____ 1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded _____ 2 PVC 4 ABS 7 Fiberglass _____ Threaded X _____ Blank casing diameter 3 1/2 in. to 20 ft. Dia _____ in. to _____ ft. Dia _____ in. to _____ ft. Dia _____ in. to _____ ft. Casing height above land surface _____ in. weight SCH 40 PVC lbs./ft. Wall thickness or gauge No. _____ TYPE OF SCREEN OR PERFORATION MATERIAL: 7 PVC 10 Asbestos-cement 1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify) _____ 2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)																																						
		SCREEN OR PERFORATION OPENINGS ARE: 5 Gauzed wrapped 8 Saw cut 11 None (open hole) 1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes 2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify) _____ SCREEN-PERFORATED INTERVALS: From 20 ft. to 25 ft. From _____ ft. to _____ ft. From _____ ft. to _____ ft. From _____ ft. to _____ ft. SAND GRAVEL PACK INTERVALS: From 19 ft. to 25 ft. From _____ ft. to _____ ft. From _____ ft. to _____ ft. From _____ ft. to _____ ft.																																						
		6 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other _____ Grout Intervals: From 20 ft. to 16 ft. From 3 1/2 ft. to 19 ft. From _____ ft. to _____ ft. What is the nearest source of possible contamination: 1 Septic tank 4 Lateral lines 7 Pit privy 10 Livestock pens 14 Abandoned water well 2 Sewer lines 5 Cess pool 8 Sewage lagoon 11 Fuel storage 15 Oil well/Gas well 3 Watertight sewer lines 6 Seepage pit 9 Feedyard 12 Fertilizer storage 16 Other (specify below) contaminated s.k. 13 Insecticide storage Direction from well? How many feet?																																						
		<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th>FROM</th> <th>TO</th> <th>LITHOLOGIC LOG</th> <th>FROM</th> <th>TO</th> <th>PLUGGING INTERVALS</th> </tr> </thead> <tbody> <tr> <td>GL</td> <td>0.50</td> <td>Asphalt</td> <td></td> <td></td> <td></td> </tr> <tr> <td>0.50</td> <td>13.00</td> <td>Silt w/Clay (ML)</td> <td></td> <td></td> <td></td> </tr> <tr> <td>13.00</td> <td>19.00</td> <td>Silty Sand (SM)</td> <td></td> <td></td> <td></td> </tr> <tr> <td>19.00</td> <td>25.00</td> <td>Sand (SW)</td> <td></td> <td></td> <td></td> </tr> <tr> <td>25.00</td> <td>TD</td> <td>End of borehole</td> <td></td> <td></td> <td></td> </tr> </tbody> </table>					FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS	GL	0.50	Asphalt				0.50	13.00	Silt w/Clay (ML)				13.00	19.00	Silty Sand (SM)				19.00	25.00	Sand (SW)				25.00	TD	End of borehole	
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS																																			
GL	0.50	Asphalt																																						
0.50	13.00	Silt w/Clay (ML)																																						
13.00	19.00	Silty Sand (SM)																																						
19.00	25.00	Sand (SW)																																						
25.00	TD	End of borehole																																						
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) <u>constructed</u> , (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 7-25-97 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 585 This Water Well Record was completed on (mo/day/year) 8-4-97 under the business name of ACI by (signature) D. J. Duncan																																								