

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Sedgwick	Fraction 1/4 SW 1/4 SW 1/4	Section number 10	Township number T 27 S	Range number R 1 W
2. Distance and direction from nearest town or city: #2 one block north of Street address of well location if in city: 13th street and 1/4			3. Owner of well West Urban Little League Inc. R.R. or street: 10008 West Ninth street City, state, zip code: Wichita, Kansas			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile NW NE SW SE X east of Skid Ridge Road Wichita, Kansas			6. Bore hole dia. 11 in. Completion date 7-27-76 Well depth 51 ft.			
5. Type and color of material			7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary			
			8. Use: ☐ Domestic ☐ Public supply ☐ Industry ☒ Irrigation ☐ Air conditioning ☐ Stock ☒ Lawn ☐ Oil field water ☐ Other			
			9. Casing: styrene Height: Above or below 12 in. Threading gl Surface 12 in. RMP ☒ PVC Weight 200 lbs./ft. Dia. 5 in. to 51 ft. depth Wall Thickness: inches or Dia. 5 in. to 51 ft. depth gage No. 200			
			10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot 1/4" .06 Length 20' Set between 31 ft. and 51 ft. Gravel pack? yes Size range of material 1-1/8"			
			11. Static water level: 20 ft. below land surface Date 7-27-76 mo./day/yr			
(Use a second sheet if needed)			12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.			
			13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____			
			14. Well head completion: 12 capped ____ Pitless adapter ____ inches above grade			
			15. Well grouted? yes With: ____ Neat cement ____ Bentonite ☒ Concrete Depth: From 40" ft. to 14 ft.			
			16. Nearest source of possible contamination: Septic Tank ft. 50 Direction South Type Tank Well disinfected upon completion? ☒ Yes ____ No			
18. Elevation: Topography: ____ Hill ____ Slope ____ Upland ____ Valley			17. Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas Signed M. Arnold Date 8-9-76 Authorized representative			
			19. Remarks: Flat Ground Water to be used for watering baseball field.			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5