

1 LOCATION OF WATER WELL:		FRACTION		Section Number		Township Number		Range Number	
Sedgwick		NW 1/4 NE 1/4 SW 1/4		3		T 27 S		R 1W E/W	

Distance and direction from nearest town or city street address of well if located within city?

North of 21st and East of Ridge Road Wichita, Kansas

2	WATER WELL OWNER:	CITY OF WICHITA		Board of Agriculture, Division of Water Resource
	RR#, ST. ADDRESS, BOX #:	P.O. Box 19163		
	CITY, STATE, ZIP CODE:	Wichita, Kansas	67277	

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX: 	<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">4 DEPTH OF COMPLETED WELL</td> <td style="width: 10%; text-align: center;">25</td> <td style="width: 10%; text-align: center;">ft.</td> <td style="width: 25%;">ELEVATION:</td> </tr> <tr> <td>Depth(s) groundwater Encountered</td> <td style="text-align: center;">1</td> <td style="text-align: center;">ft.</td> <td style="text-align: center;">2</td> </tr> <tr> <td>WELL'S STATIC WATER LEVEL</td> <td style="text-align: center;">7</td> <td colspan="2" style="text-align: center;">FT. BELOW LAND SURFACE MEASURED ON 04/20/1994</td> </tr> <tr> <td>Pump test data:</td> <td>Well water was</td> <td style="text-align: center;">ft.</td> <td>after</td> </tr> <tr> <td>Est. Yield</td> <td>gpm: Well water was</td> <td style="text-align: center;">ft.</td> <td>after</td> </tr> <tr> <td>Bore Hole Diameter</td> <td style="text-align: center;">12</td> <td style="text-align: center;">in.</td> <td style="text-align: center;">25</td> </tr> <tr> <td>WELL WATER TO BE USED AS:</td> <td>5 Public water supply</td> <td style="text-align: center;">ft.</td> <td style="text-align: center;">and</td> </tr> <tr> <td>1 Domestic</td> <td>3 Feedlot</td> <td style="text-align: center;">in.</td> <td style="text-align: center;">to</td> </tr> <tr> <td>2 Irrigation</td> <td>4 Industrial</td> <td style="text-align: center;">ft.</td> <td style="text-align: center;">ft.</td> </tr> <tr> <td></td> <td>7 Lawn and garden only</td> <td></td> <td></td> </tr> <tr> <td></td> <td>10 Monitoring well</td> <td></td> <td></td> </tr> <tr> <td colspan="4"> Was a chemical/bacteriological sample submitted to Department? Yes </td> </tr> <tr> <td colspan="4"> submitted </td> </tr> <tr> <td colspan="4"> Water Well Disinfected? Yes </td> </tr> <tr> <td colspan="4"> No </td> </tr> </table>	4 DEPTH OF COMPLETED WELL	25	ft.	ELEVATION:	Depth(s) groundwater Encountered	1	ft.	2	WELL'S STATIC WATER LEVEL	7	FT. BELOW LAND SURFACE MEASURED ON 04/20/1994		Pump test data:	Well water was	ft.	after	Est. Yield	gpm: Well water was	ft.	after	Bore Hole Diameter	12	in.	25	WELL WATER TO BE USED AS:	5 Public water supply	ft.	and	1 Domestic	3 Feedlot	in.	to	2 Irrigation	4 Industrial	ft.	ft.		7 Lawn and garden only				10 Monitoring well			Was a chemical/bacteriological sample submitted to Department? Yes				submitted				Water Well Disinfected? Yes				No			
4 DEPTH OF COMPLETED WELL	25	ft.	ELEVATION:																																																										
Depth(s) groundwater Encountered	1	ft.	2																																																										
WELL'S STATIC WATER LEVEL	7	FT. BELOW LAND SURFACE MEASURED ON 04/20/1994																																																											
Pump test data:	Well water was	ft.	after																																																										
Est. Yield	gpm: Well water was	ft.	after																																																										
Bore Hole Diameter	12	in.	25																																																										
WELL WATER TO BE USED AS:	5 Public water supply	ft.	and																																																										
1 Domestic	3 Feedlot	in.	to																																																										
2 Irrigation	4 Industrial	ft.	ft.																																																										
	7 Lawn and garden only																																																												
	10 Monitoring well																																																												
Was a chemical/bacteriological sample submitted to Department? Yes																																																													
submitted																																																													
Water Well Disinfected? Yes																																																													
No																																																													

5 TYPE OF CASING USED:		5 Wrought iron		8 Concrete tile		CASING JOINTS:		Glued ☒ Clamped	
1 Steel		6 Asbestos-Cement		9 Other (Specify below)		Welded			
2 PVC		7 Fiberglass		SDR-26		Threaded			
Blank casing Diameter 5 in. to 20 ft., Dia		in. to ft., Dia		in. to ft., Dia		in. to ft.			
Casing height above land surface 12 in., weight 2.35 lbs. / ft.		Wall thickness or gauge No. .214							
TYPE OF SCREEN OR PERFORATION MATERIAL:		5 Fiberglass		7 PVC		10 Asbestos-cement			
1 Steel		3 Stainless Steel		8 RMP (SR)		11 other (specify)			
2 Brass		4 Galvanized steel		9 ABS		12 None used (open hole)			
SCREEN OR PERFORATION OPENING ARE:		5 Gauzed wrapped		8 Saw cut		11 None (open hole)			
1 Continous slot		6 Wire wrapped		9 Drilled holes					
2 Louvered shutter		7 Torch cut		10 Other (specify)					
SCREEN-PERFORATION INTERVALS:		from 20 ft. to 25 ft., From		ft. to 25 ft., From		ft. to 25 ft., From		ft. to 25 ft., From	
GRAVEL PACK INTERVALS:		from 20 ft. to 25 ft., From		ft. to 25 ft., From		ft. to 25 ft., From		ft. to 25 ft., From	

6	GROUT MATERIAL:		1 Neat cement	2 Cement grout	3 Bentonite	4 Other	bentonite hole plug
Grout Intervals:		From 0	ft. to 20	ft. From	ft. to	ft. From	ft. to
What is the nearest source of possible contamination:							
1 Septic tank		4 Lateral lines		7 Pit privy		10 Livestock pens	
2 Sewer lines		5 Cess pool		8 Sewage lagoon		11 Fuel storage	
3 Watertight sewer lines		6 Seepage pit		9 Feedyard		12 Fertilizer storage	
						13 Insecticide storage	
						14 Abandon water well	
						15 Oil well/Gas well	
						16 Other (specify below)	
						None Apparent	
Direction from well?						How many feet?	

Direction from well?

How many feet?

[illegible]

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 04/20/1994 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236 This Water Well Record was completed on (mo/day/yr) 04/22/94 Under the business name of Harp Well & Pump Service, Inc by (signature)

Jane Frederick