


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction 1/4 NE 1/4 SE 1/4	Section number 8	Township number T 27 S	Range number R 1W E/W
2. Distance and direction from nearest town or city: Street address of well location if in city: 1723 North Byron Road Wichita, Kansas			3. Owner of well: Patrick McCarty R.R. or street: 1723 North Byron Road City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 11 in. Completion date 7-5-78 Well depth 50 ft.
Topsoil			0	3	7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary
Clay			3	15	8. Use: ☐ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☒ Lawn ☐ Oil field water ☐ Other
Fine sand			15	25	9. Casing: Material Styrene Height: Above or below Threaded ☐ Welded ☒ Surface 12 in. RMP ☒ PVC Weight 12 lbs./ft. Dia. 5 in. to 50 ft. depth Wall Thickness: inches or Dia. 5 in. to 50 ft. depth gage No. 200
Clay			25	35	10. Screen: Manufacturer's name Sunflower plastic Type styrene Dia. 5" Slot 1/16" Length 10' Set between 40 ft. and 50 ft. Gravel pack? yes Size range of material 1/4-1/8"
Medium sand			35	50	11. Static water level: 27 ft. below land surface Date 7-5-78 mo./day/yr.
					12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.
					13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____
					14. Well head completion: 12 capped ____ Pitless adapter ____ Inches above grade
					15. Well grouted? yes 1-2 fine sand mix With: ____ Neat cement ____ Bentonite ☒ Concrete Depth: From 40" ft. to 14 ft.
					16. Nearest source of possible contamination: ft. 55 Direction East Type Sewer Well disinfected upon completion? ☒ Yes ☐ No
					17. Pump: ☒ Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other
(Use a second sheet if needed)					
18. Elevation:	19. Remarks: Flat ground		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. 67209 Address M. Arnold Signed M. Arnold Date 7-5-78 Authorized representative		
Topography: ____ Hill ____ Slope ____ Upland ____ Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5