

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction 1/4 SE 1/4 SE 1/4	Section number 8	Township number T 27 S R 1W E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city: 8932 Thurman Wichita, Kansas			3. Owner of well: R. F. Porter R.R. or street: 8932 Thurman City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 11 in. Completion date 9-9-77 Well depth 60 ft.
					7. ☐ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary
					8. Use: ☐ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☒ Lawn ☐ Oil field water ☐ Other
					9. Casing: Material styrene Height: Above or below 11 Threaded ☐ Welded ☒ Surface 12 in. RMP ☐ PVC ☐ Weight 12 lbs./ft. Dia. 5 in. to 60 ft. depth Wall Thickness: inches or Dia. 5 in. to 60 ft. depth gauge No. .200
					10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/gauze .06 Length 10' Set between 50 ft. and 60 ft. ft. and 60 ft. Gravel pack? yes Size range of material 1/4-1/8"
					11. Static water level: 35 mo./day/yr. ft. below land surface Date 9-9-77
					12. Pumping level below land surfaces: ft. after 35 hrs. pumping 35 g.p.m. ft. after 35 hrs. pumping 35 g.p.m. Estimated maximum yield 35 g.p.m.
					13. Water sample submitted: 35 mo./day/yr. Yes ☐ No ☐ Date 9-9-77
					14. Well head completion: 12 well seal Pitless adapter 12 inches above grade
					15. Well grouted? yes 1-2 fine sand mix With: 40 Neat cement 14 Bentonite 14 Concrete Depth: From 40 ft. to 14 ft.
					16. Nearest source of possible contamination: City Wichita ft. 50 Direction NW Type Sewer Well disinfected upon completion? ☒ Yes ☐ No
					17. Pump: Not installed Manufacturer's name Sta-Rite Model number 20P4D02 hp 3/4 Volts 230 Length of drop pipe 50 ft. capacity 20 g.p.m. Type: ☒ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. Address Wichita, Kansas Signed M. Arnold Date 9-9-77 Authorized representative
18. Elevation:	19. Remarks: Flat Ground				
Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-3