


USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County <u>Sedgwick</u>		Fraction <u>SE 1/4 NE 1/4 NE 1/4</u>	Section number <u>9</u>	Township number <u>T 27 S</u>	Range number <u>R 1 E</u>
2. Distance and direction from nearest town or city: Street address of well location if in city: <u>7308 Bittersweet Ct</u>			3. Owner of well: <u>Jim Loyd Const.</u> R.R. or street: <u>1935 W. Ridge Rd.</u> City, state, zip code: <u>Wichita KS 67212</u>		
4. Locate with "X" in section below: 		Sketch map:		6. Bore hole dia. <u>10</u> in. Completion date <u>5-4-76</u> Well depth <u>26</u> ft.	
5. Type and color of material		From	To	7. ☐ Cable tool ☐ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☒ Bored ☐ Reverse rotary	
<u>Red Clay</u>		<u>0</u>	<u>5</u>	8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other	
<u>" Sand Fine</u>		<u>5</u>	<u>10</u>	9. Casing: Material <u>RMP</u> Height: Above or below <u>DRP</u> Threaded ☐ Welded ☐ Surface <u>12</u> in. RMP ☒ PVC ☐ Weight <u>100</u> lbs./ft. Dia. <u>6</u> in. to <u>6</u> ft. depth Wall Thickness: inches or Dia. <u>4</u> in. to <u>26</u> ft. depth gage <u>100</u>	
<u>Light Tan Sand mixed coarse</u>		<u>10</u>	<u>16</u>	10. Screen: Manufacturer's name <u>Suzflower</u> Type <u>RMP</u> Dia. <u>6</u> Slot/gauze <u>3/16</u> Length <u>5 ft</u> Set between <u>21</u> ft. and <u>25</u> ft. ft. and <u>25</u> ft. Gravel pack? <u>NO</u> Size range of material <u> </u>	
<u>" " gravel " "</u>		<u>16</u>	<u>26</u>	11. Static water level: <u>16 1/2</u> ft. below land surface Date <u>5-4-76</u> mo./day/yr.	
				12. Pumping level below land surfaces: ft. after <u> </u> hrs. pumping <u> </u> g.p.m. ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>50</u> g.p.m.	
				13. Water sample submitted: <u> </u> mo./day/yr. Yes ☐ No ☒ Date <u> </u>	
				14. Well head completion: Pitless adapter <u>12</u> inches above grade	
				15. Well grouted? <u>YES</u> With: <u> </u> Neat cement <u> </u> Bentonite ☒ Concrete Depth: From <u>0</u> ft. to <u>11</u> ft.	
				16. Nearest source of possible contamination: <u>SANITARY</u> Type <u>PHASE</u> Well disinfected upon completion? Yes ☒ No ☐	
				17. Pump: ☒ Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other	
18. Elevation:		(Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Protheroe Pump & Well</u> <u>295</u> Business name <u>827 W 27th St</u> License No. <u> </u> Address <u>Wichita KS 67212</u> Signed <u> </u> Date <u>5-4-76</u> Authorized representative	
19. Remarks:					
Topography: ☐ Hill ☐ Slope ☐ Upland ☒ Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5