

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County: <u>Sedgwick</u>	Fraction: <u>NE 1/4 SE 1/4 NE 1/4</u>	Section number: <u>19</u>	Township number: <u>T 27 S</u>	Range number: <u>R 1 E</u>
2. Distance and direction from nearest town or city:		3. Owner of well: <u>A.L. Bradshaw Inc.</u>				
Street address of well location in city:		Rt. or street: <u>409 N. Maize Rd. Wichita</u>				
4. Locate with "X" in section below:		City, state, zip code: <u>Wichita KS 67212</u>				
Sketch map:		6. Bore hole dia. <u>5</u> in. Completion date: <u>4/24/78</u>				
N W E S 1 Mile		Well depth: <u>81</u> ft.				
Existing machine Shop.		7. <u>X</u> Cable tool <u>X</u> Rotary <u> </u> Driven <u> </u> Dug				
new office & Shop. X → Well		<u> </u> Hollow rod <u> </u> Jetted <u> </u> Bored <u> </u> Reverse rotary				
MAIZE RD.		8. Use: <u>X</u> Domestic <u> </u> Public supply <u> </u> Industry				
		<u> </u> Irrigation <u> </u> Air conditioning <u> </u> Stock				
		<u> </u> Lawn <u> </u> Oil field water <u> </u> Other				
		9. Casing: Material <u>Steel</u> Weight: <u>4</u> ft.				
		Threaded <u> </u> Welded <u> </u> Surface <u> </u>				
		RMP <u>X</u> PVC <u> </u> Weight: <u>1.50</u> lbs./ft.				
		Dia. <u>5</u> in. to <u>81</u> ft. depth Wall Thickness: inches or				
		Dia. <u> </u> in. to <u> </u> ft. depth Gauge No. <u>200</u>				
5. Type and color of material		10. Screen: Manufacturer's name: <u>Sunflower</u>				
From To		Type <u>200</u> Dia. <u>5</u> in.				
Top soil		Slot gauge <u>1 1/16</u> Length <u>5</u> ft.				
Red clay		Set between <u>7</u> ft. and <u>8</u> ft.				
fine & med sand		Gravel pack? <u>Yes</u> Size range of material: <u>3/8</u>				
gray & red clay		11. Static water level: <u>10</u> ft. below land surface Date: <u>4/24/78</u>				
medium gravel		12. Pumping level below land surfaces:				
clay		<u>11</u> ft. after <u>1/2</u> hrs. pumping <u>20</u> g.p.m.				
		<u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m.				
		Estimated maximum yield <u>45</u> g.p.m.				
		13. Water sample submitted: <u> </u> Yes <u>X</u> No Date: <u> </u>				
		14. Well head completion: <u>4</u> ft. above grade				
		<u> </u> Pitless adapter <u> </u>				
		15. Well grouted? <u>Yes</u>				
		With: <u> </u> Neat cement <u> </u> Bentonite <u>X</u> Concrete				
		Depth: From <u>0</u> ft. to <u>10</u> ft.				
		16. Nearest source of possible contamination: <u>100</u> ft. Direction <u>S.W.</u> Type <u>Creek</u>				
		Well disinfected upon completion? <u>X</u> Yes <u> </u> No				
		17. Pump: <u>X</u> Not installed				
		Manufacturer's name <u> </u>				
		Model number <u> </u> HP <u> </u> Volts <u> </u>				
		Length of drop pipe <u> </u> ft. capacity <u> </u> g.p.m.				
		Type: <u> </u> Submersible <u> </u> Turbine				
		<u> </u> Jet <u> </u> Reciprocating				
		<u> </u> Centrifugal <u> </u> Other				
18. Elevation:		20. Water well contractor's certification:				
19. Remarks:		This well was drilled under my jurisdiction and this report is to the best of my knowledge and belief.				
Topography: <u> </u> Hill <u> </u> Slope <u> </u> Upland <u>X</u> Valley		<u>Weninger Drilling</u> 318				
		Business name <u> </u> License No. <u> </u>				
		Address <u> </u>				
		Signed <u> </u> Date <u>4/24/78</u>				
		Authorized representative				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5