

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County SEDGWICK	Fraction 1/4 SE 1/4 SW 1/4		Section number 21	Township number T 27 S	Range number R 1W E/W		
2. Distance and direction from nearest town or city: 233 So. Socora Wichita, Kansas					3. Owner of well: Alfred Brown R.R. or street: 1103 No. Sheridan City, state, zip code: Wichita, Kansas				
4. Locate with "X" in section below: N S 1 Mile					Sketch map:				
5. Type and color of material					From	To			
					Topsoil		0	3	
					Clay		3	15	
					Fine Sand		15	35	
					Medium Sand with Silt		35	50	
					Fine Sand		50	95	
					Medium Sand		95	115	
6. Bore hole dia. 11 in. Completion date 6-15-78 Well depth 115 ft.					7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary				
8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other					9. Casing: Material styrene Height: Above or below 464 Threaded ☐ Welded ☒ Surface 12 in. RMP ☒ PVC ☐ Weight 12 lbs./ft. Dia. 5 in. to 115 ft. depth Wall Thickness: inches or Dia. 5 in. to 115 ft. depth gage No. 200				
10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot 1/4" .06 Length 15' Set between 100 ft. and 115 ft. Gravel pack? yes Size range of material 1/4-1/8"					11. Static water level: 30 ft. below land surface Date 6-15-78 mo./day/yr.				
12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.					13. Water sample submitted: ____ mo./day/yr. ____ Yes ____ No Date ____				
14. Well head completion: capped ____ Pitless adapter 12 inches above grade					15. Well grouted? yes 1-2 Fine Sand Mix With: ____ Neat cement ____ Bentonite ☒ Concrete Depth: From 40" ft. to 14 ft.				
16. Nearest source of possible contamination: ft. ____ Direction ____ Type NONE Well disinfected upon completion? ☒ Yes ____ No					17. Pump: ☒ Nat installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: ____ Submersible ____ Turbine ____ Jet ____ Reciprocating ____ Centrifugal ____ Other				
18. Elevation:					19. Remarks: Flat Ground Septic System not installed at this time. No apparent source for contamination.				
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Ornel Date 6-15-78 Authorized representative									

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5