


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County SEDGWICK	Fraction 1/4 SE 1/4 SW 1/4	Section number 21	Township number T 27	Range number S R 1W E/W
2. Distance and direction from nearest town or city: 207 So. Socora Wichita, Kansas			3. Owner of well: E.E. Oliphant R.R. or street: 8406 Maple City, state, zip code: Wichita, Kansas		
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile			Sketch map: 		
5. Type and color of material			From	To	6. Bore hole dia. 11 in. Completion date _____ Well depth 120 ft. 6-15-78
Topsoil			0	3	7. Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary
Clay			3	15	8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other
Fine Sand			15	30	9. Casing: Material styrene Height: Above or below Threaded ☐ Welded ☒ Surface 12 in. RMP ☒ PVC ☐ Weight _____ lbs./ft.
Medium Sand			30	45	Dia. 5 in. to 120 depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gauge No. 200
Fine Sand			45	100	10. Screen: Manufacturer's name _____ Sunflower Plastic Type styrene Dia. 5" Slot .06 Length 20' Set between 100 ft. and 120 ft. Gravel pack? yes Size range of material 1/4-1/8"
Medium Sand			100	120	11. Static water level: _____ mo./day/yr. 30 ft. below land surface Date 6-15-78
					12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
					13. Water sample submitted: _____ mo./day/yr. Yes ☐ No ☐ Date _____
					14. Well head completion: CAPPED Pitless adapter 12 Inches above grade
					15. Well grouted? yes 1-2 Fine Sand Mix With: Neat cement ☐ Bentonite ☒ Concrete ☐ Depth: From 40" ft. to 14 ft.
					16. Nearest source of possible contamination: ft. _____ Direction _____ Type NONE Well disinfected upon completion? ☒ Yes ☐ No
					17. Pump: ☒ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other
18. Elevation:			19. Remarks: Flat Ground Septic System not installed at this time. No apparent source for contamination. Well is to be inside of building.		
Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name License No. Address Wichita, Kansas 67209 Signed M. Arnold Date 7-27-78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5