


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Sedgwick	Fraction NW 1/4 NW 1/4 SE 1/4	Section number 24	Township number T 27 S R 1	Range number 1
2. Distance and direction from nearest town or city: Street address of well location if in city:		3. Owner of well: City, state, zip code:			
220 South Sheridan Wichita, Kansas		J. D. Construction 9817 Kenny Kansas Kansas			
4. Locate with "X" in section below: Sketch map: 		6. Bore hole dia. 11 in. Completion date 11-23-76 Well depth 43 ft.			
5. Type and color of material		7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary			
Sandy Soil		8. Use: ☐ Domestic ☐ Public supply ☐ Industry ☒ Irrigation ☐ Air conditioning ☐ Stock ☒ Lawn ☐ Oil field water ☐ Other			
Clay		9. Casing: Material styrene Above or below Threaded ☐ Welded ☒ Surface 12 in. RMP ☒ PVC ☐ Weight ☐ lbs./ft. Dia. 5 in. to 43 ft. depth Wall Thickness: inches or Dia. ☐ in. to ☐ ft. depth gage No. 200			
Medium Sand		10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/gage .06 Length 15' Set between 28 ft. and 43 ft. ☐ ft. and ☐ ft. Gravel pack? yes Size range of material 1-1/8"			
		11. Static water level: 16 ft. below land surface Date 11-23-76 mo./day/yr.			
		12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.			
		13. Water sample submitted: ☐ Yes ☐ No Date			
		14. Well head completion: 12 capped Pitless adapter ☐ Inches above grade			
		15. Well grouted? yes With: ☐ Neat cement ☒ Bentonite ☐ Concrete Depth: From 40" to 14' City Wichita			
		16. Nearest source of possible contamination: Sewer Line ft. 50 Direction West Type Line Well disinfected upon completion? ☒ Yes ☐ No			
		17. Pump: ☒ Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other			
18. Elevation:		19. Remarks: Flat Ground		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. Address Signed M. Arnold Date 3-4-77 Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5