


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 820-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

SW SE NE NE

1. Location of well:		County Sedgwick	Fraction 1/4 NE 1/4 NE 1/4	Section number 29	Township number T 27 S R 1W E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:		443 South Westfield Wichita, Kansas		3. Owner of well: R.R. or street: City, state, zip code: George McClellan Construction 9505 West Central Wichita, Kansas 67212		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map: 		6. Bore hole dia. 11 in. Completion date 12-19-77 Well depth 75 ft.		
5. Type and color of material		From	To	7. ☒ Cable tool ☒ Rotary ☐ Driven ☐ Dug ☐ Hollow rod ☐ Jetted ☐ Bored ☐ Reverse rotary		
				8. Use: ☒ Domestic ☐ Public supply ☐ Industry ☐ Irrigation ☐ Air conditioning ☐ Stock ☐ Lawn ☐ Oil field water ☐ Other		
				9. Casing: Material styrene Height: Above or below Threaded ☐ Welded ☒ Surface 12 in. RMP ☒ PVC ☐ Weight ☐ lbs./ft. Dia. 5 in. to 75 ft. depth Wall Thickness: inches or Dia. ☐ in. to ☐ ft. depth gage No. .200		
				10. Screen: Manufacturer's name Sunflower Plastic Type styrene Dia. 5" Slot/gauge 1/16 Length 20' Set between 30 ft. and 42 ft. 67 ft. and 75 ft. Gravel pack? yes Size range of material 1/4-1/8"		
				11. Static water level: ☐ mo./day/yr. 25 ft. below land surface Date 12-19-77		
				12. Pumping level below land surfaces: ☐ ft. after ☐ hrs. pumping ☐ g.p.m. ☐ ft. after ☐ hrs. pumping ☐ g.p.m. Estimated maximum yield ☐ g.p.m.		
				13. Water sample submitted: ☐ mo./day/yr. ☐ Yes ☐ No Date ☐		
				14. Well head completion: ☐ Pitless adapter 12 capped Inches above grade		
				15. Well grouted? yes 1-2 fine sand mix With: ☐ Neat cement ☐ Bentonite ☐ Concrete Depth: From 40 ft. to 14 ft.		
				16. Nearest source of possible contamination: Septic Tank ft. 70 Direction South Type Tank Well disinfected upon completion? ☒ Yes ☐ No		
				17. Pump: ☒ Not installed Manufacturer's name ☐ Model number ☐ HP ☐ Volts ☐ Length of drop pipe ☐ ft. capacity ☐ g.p.m. Type: ☐ Submersible ☐ Turbine ☐ Jet ☐ Reciprocating ☐ Centrifugal ☐ Other		
		(Use a second sheet if needed)				
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Harp Well & Pump 236 Business name Wichita, Kansas License No. 67209 Address Wichita, Kansas Signed M. Arnold Date 1-10-78 Authorized representative		
Topography: ☐ Hill ☐ Slope ☐ Upland ☐ Valley		Flat Ground				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5