

1 LOCATION OF WATER WELL: County: <u>Sedgwick</u>		Fraction: <u>SE 1/4 NW 1/4 NE 1/4</u>	Section Number: <u>29</u>	Township Number: <u>T 27 S</u>	Range Number: <u>R 1 E/W</u>
Distance and direction from nearest town or city street address of well if located within city? <u>See Below</u>					
2 WATER WELL OWNER: <u>Charles Weems</u>					
RR#, St. Address, Box # : <u>501 Cheryl</u>			Board of Agriculture, Division of Water Resources		
City, State, ZIP Code : <u>Wichita KS 67212</u>			Application Number:		
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL: <u>96</u> ft. ELEVATION: <u>35</u> ft.			
		Depth(s) Groundwater Encountered 1. <u>35</u> ft. 2. <u>85</u> ft. 3. <u>96</u> ft.			
		WELL'S STATIC WATER LEVEL <u>85</u> ft. below land surface measured on mo/day/yr <u>10-19-98</u>			
		Pump test data: Well water was _____ ft. after _____ hours pumping _____ gpm			
		Est. Yield _____ gpm: Well water was _____ ft. after _____ hours pumping _____ gpm			
		Bore Hole Diameter: _____ in. to _____ ft. and _____ in. to _____ ft.			
		WELL WATER TO BE USED AS:			
		☒ 1 Domestic ☐ 3 Feedlot ☐ 6 Oil field water supply ☐ 9 Dewatering ☐ 12 Other (Specify below)			
		☐ 2 Irrigation ☐ 4 Industrial ☐ 7 Lawn and garden only ☐ 10 Monitoring well			
		Was a chemical/bacteriological sample submitted to Department? Yes _____ No <u>X</u> ; If yes, mo/day/yr sample was submitted _____			
		Water Well Disinfected? Yes <u>X</u> No <u>X</u>			
5 TYPE OF BLANK CASING USED:					
☒ 1 Steel ☐ 3 RMP (SR) ☒ 2 PVC ☐ 4 ABS		☐ 5 Wrought iron ☐ 6 Asbestos-Cement ☐ 7 Fiberglass		☐ 8 Concrete tile ☐ 9 Other (specify below) ☐ 10 Asbestos-cement	
Blank casing diameter <u>5</u> in. to <u>88</u> ft. Dia. <u>2.60</u> in. to _____ ft. Dia. _____ in. to _____ ft.		Casing height above land surface <u>12</u> in., weight _____ lbs./ft. Wall thickness or gauge No. <u>100 AK</u>			
TYPE OF SCREEN OR PERFORATION MATERIAL:					
☐ 1 Steel ☐ 3 Stainless steel ☐ 5 Fiberglass ☐ 8 RMP (SR) ☐ 2 Brass ☐ 4 Galvanized steel ☐ 6 Concrete tile ☐ 9 ABS		☒ 7 PVC ☐ 10 Asbestos-cement ☐ 11 Other (specify) _____ ☐ 12 None used (open hole)			
SCREEN OR PERFORATION OPENINGS ARE:					
☐ 1 Continuous slot ☒ 3 Mill slot ☐ 5 Gauzed wrapped ☐ 8 Saw cut ☐ 11 None (open hole) ☐ 2 Louvered shutter ☐ 4 Key punched ☐ 6 Wire wrapped ☐ 9 Drilled holes ☐ 10 Other (specify) _____					
SCREEN-PERFORATED INTERVALS: From <u>88</u> ft. to <u>96</u> ft. From _____ ft. to _____ ft.					
GRAVEL PACK INTERVALS: From <u>23</u> ft. to <u>96</u> ft. From _____ ft. to _____ ft.					
6 GROUT MATERIAL:					
☒ 1 Neat cement ☒ 2 Cement grout ☐ 3 Bentonite ☐ 4 Other					
Grout Intervals: From <u>3</u> ft. to <u>23</u> ft. From _____ ft. to _____ ft.					
What is the nearest source of possible contamination:					
☐ 1 Septic tank ☐ 4 Lateral lines ☐ 7 Pit privy ☐ 10 Livestock pens ☐ 14 Abandoned water well ☐ 2 Sewer lines ☐ 5 Cess pool ☐ 8 Sewage lagoon ☐ 11 Fuel storage ☐ 15 Oil well/Gas well ☒ 3 Watertight sewer lines ☐ 6 Seepage pond ☐ 9 Feedyard ☐ 12 Fertilizer storage ☐ 16 Other (specify below)		☐ 13 Insecticide storage ☐ 17 Other (specify below)			
Direction from well? <u>West</u> How many feet? <u>100 ft.</u>					
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	2	top soil	79	94	Sand med.
2	18	clay	94	96	clay
18	30	fine sand			
30	48	med. Sand			
48	60	clay			
60	78	fine sand			
78	79	clay			
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was ☒ (1) constructed, ☐ (2) reconstructed, or ☐ (3) plugged under my jurisdiction and was completed on (mo/day/year) <u>10-19-98</u> and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. <u>318</u> This Water Well Record was completed on (mo/day/yr) <u>10-22-98</u> under the business name of <u>Weninger Drilling LLC</u> by (signature) <u>Susan K. Weninger</u>					