

1	LOCATION OF WATER WELL:	Fraction	Section Number	Township Number	Range Number
County:	SEDGWICK	NE ¼ NE ¼ NE ¼	31	T 27 S	R 1 W EW

Distance and direction from nearest town or city street address of well if located within city?

10725 West Kellogg Wichita, KS.

2	WATER WELL OWNER:	Coastal Mart	
	RR#, St. Address, Box # :	10725 West Kellogg	Board of Agriculture, Division of Water Resources
	City, State, ZIP Code :	Wichita, KS.	Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

1 Mile

W E

N S

4 DEPTH OF COMPLETED WELL... 120... ft. ELEVATION:

Depth(s) Groundwater Encountered 1. ft. 2. ft. 3. ft.

WELL'S STATIC WATER LEVEL ... 25... ft. below land surface measured on mo/day/yr ... 11-8-89

Pump test data: Well water was ft. after hours pumping gpm

Est. Yield gpm: Well water was ft. after hours pumping gpm

Bore Hole Diameter ... 11... in. to ft., and in. to ft.

WELL WATER TO BE USED AS:

5 Public water supply	8 Air conditioning	11 Injection well
1 Domestic	3 Feedlot	6 Oil field water supply
2 Irrigation	4 Industrial	7 Lawn and garden only
		9 Dewatering
		10 Monitoring well
		12 Other (Specify below)

Was a chemical/bacteriological sample submitted to Department? Yes.....No...XX...; If yes, mo/day/yr sample was submitted

Water Well Disinfected? Yes XX No

5 TYPE OF BLANK CASING USED:		5 Wrought iron	8 Concrete tile	CASING JOINTS: Glued <u>XX</u> Clamped
1 Steel	3 RMP (SR)	6 Asbestos-Cement	9 Other (specify below)	Welded
2 PVC	4 ABS	7 Fiberglass	<u>Cer-Mac styrene SDR-26</u>	Threaded
Blank casing diameter 5 in. to 100 ft., Dia in. to ft., Dia in. to ft.				
Casing height above land surface 12 in., weight 1.59 lbs./ft. Wall thickness or gauge No. . . . 203				
TYPE OF SCREEN OR PERFORATION MATERIAL:		7 PVC	10 Asbestos-cement	
1 Steel	3 Stainless steel	8 RMP (SR)	11 Other (specify)	
2 Brass	4 Galvanized steel	9 ABS	12 None used (open hole)	
SCREEN OR PERFORATION OPENINGS ARE:		5 Gauzed wrapped	8 Saw cut	11 None (open hole)
1 Continuous slot	3 Mill slot	6 Wire wrapped	9 Drilled holes	
2 Louvered shutter	4 Key punched	7 Torch cut	10 Other (specify)	
SCREEN-PERFORATED INTERVALS:		From 100 ft. to 120 ft., From ft. to ft.		
		From ft. to ft., From ft. to ft.		
GRAVEL PACK INTERVALS:		From 24 ft. to 120 ft., From ft. to ft.		
		From ft. to ft., From ft. to ft.		

6 GROUT MATERIAL:		1 Neat cement	2 Cement grout	3 Bentonite	4 Other
Grout Intervals:		From 4 ft. to 24 ft.	From	ft. to	ft. to
What is the nearest source of possible contamination:			10 Livestock pens		
1 Septic tank	4 Lateral lines	7 Pit privy	14 Abandoned water well		
2 Sewer lines	5 Cess pool	8 Sewage lagoon	11 Fuel storage		
3 Watertight sewer lines	6 Seepage pit	9 Feedyard	12 Fertilizer storage		
			13 Insecticide storage		
Direction from well?			15 Oil well/Gas well		
			16 Other (specify below)		
			None apparent		
			How many feet?		

[illegible]

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was completed on (mo/day/year) 11-8-89 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 236 This Water Well Record was completed on (mo/day/yr) 4-10-90 under the business name of Harp Well & Pump Service, Inc. by (signature) Mari Arnold

INSTRUCTIONS: Use typewriter or ball point pen. PLEASE PRESS FIRMLY and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send 3 three copies to Kansas Department of Health and Environment, Bureau of Water Protection, Topeka, Kansas 66620-7320. Telephone: 913-296-5514. Send one to WATER WELL OWNER and retain one for your records.