


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>SEDGWICK</b>	Township name <b>Delano</b>	Fraction <b>NE 1/4 NE 1/4 SE 1/4</b>	Section number <b>34</b>	Town number <b>T275</b>	Range number <b>R1W</b>
Distance and direction from nearest town or city:			3 Owner of well: <b>THORNTON COMPANY</b>			
Street address of well location if in city: <b>1701 So. HOOPER</b>			Address: <b>1701 So. HOOPER, Wichita, KS.</b>			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map: <b>KANSAS</b>			4 Well depth: <b>46</b> ft. Date of completion: <b>11-15-74</b> Well diameter <b>11</b> in.
2 Type and color of material  <b>Fine sand</b> <b>med. COARSE SAND</b> <b>AND FINE GRAVEL</b>			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> <b>Warehouse restroom</b>	
					7 Casing: Material <b>PVC</b> Height: <b>above</b> /below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>12</b> in. Diam. _____ Weight _____ lbs./ft. _____ <b>5</b> in. to <b>46</b> ft. depth! Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No _____ in. to _____ ft. depth!	
					8 Screen: <b>Ralph Jones Jet Stream</b> Manufacturer <b>PLASTIC</b> Type <b>PVC</b> Dia. <b>5 1/2</b> Slot/gauze <b>.050</b> Length <b>10 ft.</b> Set between <b>36</b> ft. and <b>46</b> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <b>1/4" to 1/8"</b>	
					9 Static water level: <b>15</b> ft. below land surface Date <b>11-15-74</b>	
					10 Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input type="checkbox"/> No Date _____	
					12 Well head completion: <b>capped</b> <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From <b>0</b> ft. to <b>12</b> ft.	
					14 Nearest source of possible contamination: <b>SEPTIC SYSTEM</b> ft. _____ Direction <b>NOT IN</b> Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
(use a second sheet if needed)					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>HARP WELL PUMP SERV. 236</b> Business name _____ License No. _____ Address <b>215 So. TYLER</b> Signed <b>[Signature]</b> Date <b>11-15-74</b> Authorized representative	
16 Remarks: elevation <b>SEPTIC SYSTEM NOT IN WHEN DRILLED</b>						
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						