

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Pratt	Fraction SW 1/4 SW 1/4 S 1/4	Section number 5	Township number T 27 S R 11 E/W	Range number 11
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Belle Williams R.R. or street: 515 W 1st Pratt, Ks. City, state, zip code:		
4. Locate with "X" in section below: Sketch map:			6. Bore hole dia. 8 in. Completion date 4-29-78 Well depth 98 ft.		
			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material			9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface _____ in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 98 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage N258		
			10. Screen: Manufacturer's name _____ Pumpeo Type pvc Dia. 5 Slot/gauze 0.30 Length 10 Set between 88 ft. and 98 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 in		
			11. Static water level: _____ mo./day/yr. 46 ft. below land surface Date 4-29-78		
			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 100 g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 83 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. 100 Direction N Type lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: Not installed _____ Manufacturer's name Jacuzzi Bros Model number 7540 HP 3/4 Volts 230 Length of drop pipe 75 ft. capacity 20 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			(Use a second sheet if needed)		
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: customer to pour slab			
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Lyman Bros . 140 Business name License No. Address Mod. Lodge Signed W W Lyman Date 5-1- Authorized representative			

22
 11
 W
 5
 SUSK SE
 1/4 1/4 NW

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5