

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Pratt	Fraction NW 1/4 SE 1/4 SW 1/4	Section number 26	Township number T 27 S R 11	Range number 11
2. Distance and direction from nearest town or city: 12 miles East of Pratt, KS Street address of well location if in city:			3. Owner of well: Gary Fitzsimmons R.R. or street: Route 2 City, state, zip code: Cunningham, KS 67035		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 24 in. Completion date 7-11-78 Well depth 50 ft.	
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		Well #1		9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30.3 lbs./ft. Dia. 16 in. to 20 ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. 7 ga.	
		From		10. Screen: Manufacturer's name W. A. Brown	
Sandy top soil		0		Type Double-slot Dia. 16"	
Black & blue clay		4		<input checked="" type="checkbox"/> Slot gauze 1/8" Length 30'	
Sand & gravel		37		Set between 20 ft. and 50 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft.	
Sandy clay & soft sandstone		47		Gravel pack? Yes Size range of material 3/8-200	
				11. Static water level: _____ mo./day/yr. N/C ft. below land surface Date _____	
				12. Pumping level below land surfaces: XXX 20 ft. after 8 hrs. pumping 500 g.p.m. 20 ft. after 24 hrs. pumping 500 g.p.m. Estimated maximum yield 600 g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: Field ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Berkeley <input checked="" type="checkbox"/> Model number B4JRBM HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: Engine driven-318 Chrysler <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input checked="" type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation:		19. Remarks: This is a manifold system consisting of 2 wells 50' apart		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name _____ License No. _____ Address Great Bend, KS 67530 Signed [Signature] Date 1-9-79 Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T
R
W
S
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5