WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section number		Township number	Range number		
1. Location of well:	Pratt	1/4 1/4 CS	E1/4	12	2	T 27 s	_R 12	EW)	
11 miles Northeast of Pratt, KS R.R. or s Street address of well location if in city:				er of well: Willard B. Thompson street: Box 997 ste, zip code: Wichita, KS 67201					
4. Locate with "X" in section below: Sketch map:						6. Bore hole dia. <u>24</u> in. Well depth <u>56</u> ft.	Completion date	988 0 1-77	
NW NE						7 Cable tool Rotary Driven Dug Hollow rod Jetted Bored X Reverse rotary 8. Use: Domestic Public supply Industry			
E E S S Mile S Mile S S S S S S S S S						X Irrigation Air conditioning Stock Lawn Oil field water Other 9. Casing: Material Steel Height Above or below			
						Threaded Welded Surface 12_ in. RMP PVC Weight 30.3_ lbs./ft. Dig. 16 in. to 90			
5. Type and color of material				From	То	Dia. 16 in. to 124 ft. depth gage No. 7 ga. 10. Screen: Manufacturer's name			
Top soil					3	Type	Dig. 16''		
Sand & gravel & clay streak at 19'				3	41	Slot/gauze 1/8 Length 30 ' Set between 90 ft. and 120 ft.			
Brown XXXX clay				41	43	ft. andft. Gravel pack? <u>YES</u> Size range of material 3/8-200			
Sand & gravel streak aty 62'				43	76	11. Static water level: mo./day/yr. 56 ft. below land surface Date 4-8-77			
Gray clay				76	89	12. Pumping level below land surfaces: N/C			
Sand & gravel				89	113	ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m.			
Sand & gravel with thin clay streaks				113	119	Estimated maximum yieldg.p.m. 13. Water sample submitted:mo./day/yr.			
Gray clay				119	121	14. Well head completion:	Pate		
Sand & gravel				121	124	Pitless adapter 12 Inches above grade 15. Well grouted? <u>VES</u>			
					With: X Neat cement Bentonite Concrete Depth: From O ft. to 10 ft.				
						16. Nearest source of possible	contamination: FI	ELD	
						ft Direction Type Well disinfected upon completion? Yes XXX No			
						101/0 6	Not installed	460 " \	
							_ HP <u></u>	<u>, 460</u> g.p.m. ₹	
						Type: Submersible	X Turbine		
(Use a second sheet if needed)						Jet Centrifugal	Recipro	cating	
18. Elevation:	19. Remarks:					20. Water well contractor's co This well was drilled under my		report N	
Topography:						is true to the best of my knowl Clarke Well & Ed		85 💈	
Hill Slope						Business name Address Great Bend, KS 67530			
Upland Valley						Signed Authorized representative			
Enguard the white, blue and pink copies to the Department of Health and Environment									