


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Pratt	Township name Logan	Fraction NE1/4SE1/4	Section number 19	Town number 27	Range number 12
Distance and direction from nearest town or city: 2N 3E Pratt			3 Owner of well: Kenneth Lawton			
Street address of well location if in city:			Address: RFD 2 Pratt			
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: 62 ft. Date of completion 6-6-75 Well diameter 10 in.
2 Type and color of material			From To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input checked="" type="checkbox"/> Stock Well	
					7 Casing: Material RMP Height: above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. Diam. 3/4 in. Weight 200 lbs./ft 62 5 in. to 62 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No — in. to — ft. depth	
					8 Screen: Manufacturer Jess & Lowell Type RMP Dia. 5" Slot/gauze 3/16 Length 10' Set between 52 ft. and 62 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4-3/8	
					9 Static water level: 38 ft. below land surface Date 6-6-75	
					10 Pumping level below land surfaces: — ft. after — hrs. pumping — g.p.m. — ft. after — hrs. pumping — g.p.m. Estimated maximum yield 100 g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date —	
					12 Well head completion: Well Seal <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade 24"	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> 940# Portland Depth: From 0 ft. to 10 ft.	
					14 Nearest source of possible contamination: ft. 660 Direction NW Type Ceplio Tank Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
(use a second sheet if needed)			15 Pump: Wind Mill <input type="checkbox"/> Not installed Manufacturer's name — Model number — HP — Volts — Length of drop pipe 42 ft. capacity 700 g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Other			
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Hank Bruce Well Ser. 103 Business name License No. Address 117 STOUT Pratt Signed Joyce Bruce Date 6-29-75 Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5