

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well: County <u>Pratt</u> Fraction <u>SE 1/4 SE 1/4 SW 1/4</u> Section number <u>7</u> Township number <u>T 27 S</u> Range number <u>R 13 W E/W</u>				
2. Distance and direction from nearest town or city: <u>3N & 2W of Pratt</u> 3. Owner of well: <u>H-30 Inc</u> Street address of well location if in city: <u>Pratt</u> R.R. or street: City, state, zip code: <u>Wichita, Ks</u>				
4. Locate with "X" in section below: Sketch map: <div style="display: flex; align-items: center;"> <div style="margin-right: 20px;"> <p style="text-align: center;">N</p> <p style="text-align: center;">S</p> </div> <div> <p style="text-align: center;">X drainage</p> </div> </div>				
5. Type and color of material				
<u>Soil</u>	From	To	6. Bore hole dia. <u>10</u> in. Completion date <u>25 Jan 78</u> Well depth <u>120</u> ft.	
<u>Clay, tan and brown</u>	0	2	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
<u>Clay, tan</u>	2	12	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other	
<u>Sand, fine to coarse and fine to coarse gravel</u>	12	55	9. Casing: Material <input type="checkbox"/> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <u>5</u> in. to <u>100</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>1258</u>	
<u>Clay, tan</u>	55	92	10. Screen: Manufacturer's name <u>Pierless</u> Type <u>Saw slot</u> Dia. <u>5"</u> Slot/gauze <u>1/8</u> Length <u>30'</u> Set between <u>100</u> ft. and <u>120</u> ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/8 x 1/4</u>	
<u>Sand, med. to coarse and med. to very coarse gravel</u>	92	98	11. Static water level: <input type="checkbox"/> mo./day/yr. <u>65</u> ft. below land surface Date <u>25 Jan 78</u>	
<u>Clay, tan and white</u>	98	123	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <u>50</u> g.p.m.	
<u>Sand, fine to coarse and fine to med. gravel</u>	123	128	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
	128	135	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade	
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <u>None</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Central Well & Pump Svc.</u> <u>325</u> Business name License No. Address <u>121 S. Taylor Pratt, Ks.</u> Signed <u>E. Benomihl</u> Date <u>24 Feb 78</u> Authorized representative	
18. Elevation:	19. Remarks:		21. Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	

T 27 S R 13 W E/W

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5