WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section number		Township number	Range number	
1. Location of well:	Pratt	1/4 1/4 CNW	1/4	3	0	τ 27 s	R 13	E.
4 mi. Northwest of Pratt, KS				3. Owner of well: George Soeken R.R. or street: (?)				
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. 24 in. Completion date 6-16-76 Well depth 140 ft.			<u>-16-7</u> 6	
NW NE						7 Cable tool Rotary Driven Dug Hollow rod Jetted Bored X Reverse rotary 8. Use: Domestic Public supply Industry		erse rotary
E E S S S S S S S S						X Irrigation Air conditioning Stock Lawn Oil field water Other 9. Casing: Material Steel Height Above or below		
						Threaded Welded Kourface in. RMP PVC Weight 30 • 3 lbs./ft. Dia . 16 in. to 50t. depth Wall Thickness; inches or		
5. Type and color of			,	From	То	Dia. 16 in. to 100t. dept	th Wall Thickness: ir th gage No. 7 8	ches or
Sandy top soil				0	2	10. Screen: Manufacturer's name		
Brown & gray clay				2	23	Set between 50 ft. and 60 ft.		
Sandy clay streaks, sand, & limestone				23	46	100 ft. a		
Sand & gravel				46	59	11. Static water level: mo./day/yr. 18ft. below land surface Date 12-29-75		
Brown & gray clay & limestone				59	86	12. Pumping level below land		- 1
Sandy clay & sandstone				86	98	ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
Sand, gravel & KNIK fine clay streaks				98	111	13. Water sample submitted:		./day/yr.
Brown clay & limestone				111	116	14. Well head completion:		
Sand, gravel & thin clay streaks				116	136	Pitless adapter 15. Well grouted? Yes	12 Inches above	grade
Brown clay				136	140	Depth: From tt. to ft.		
						NONE KNOW 16. Negrest source of possible ft Direction		
						Well disinfected upon comple 17. Pump:	tion? Yes	X No
				<u> </u>		Manufacturer's name FMC		
						Length of drop pipe 70	ft. capacity 900	
						Type: Submersible	<u>X</u> Turbin	1 1.
(Use a second sheet if needed)						Jet Centrifugal	Recipro	ocating S
18. Elevation: 19. Remarks:						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
Topography: ———————————————————————————————————					Clarke Well & Eq., Inc. 185 Business name Creat Rand, VC			
Slope Upland Valley						Signed Authorized repr	clark Bate	6-23-76