WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

— т		Υ					
J. Location of well:	County	Fraction		Section number		Township number Range number	
a. Localion of well:	pratt	1/4	C 1/4 SV	1/4	36	<u> </u>	T 2627 S R 13 EW
1					vner of well:		DaMac Drilling
Street address of well location if in city:				r street:		Box 1164	
City, st				state, zip code:		Great Bend, Kansas 67530	
4. Locate with "X" in section below: N							6. Bore hole dia. 8 in. Completion date Well depth 110 ft. 11-11-75
							7 Cable tool X_ Rotary Driven Dug
							Hollow rod Jetted Bored Reverse rotary
							8. Use: Domestic Public supply Industry
							Irrigation Air conditioning Stock Lawn Oil field water Other
							9. Casing: Material Height: Above or bytev
							Threaded WeldediSurfacein.
S 1 Mile	la						RMPPVCXWeightlbs./ft. Dia. 44 in. t110 ft. depth Wall Thickness: inches or
5. Type and color of material					From	То	Diain. to ft. depth gage No 237
7,50 0000 00 00							10. Screen: Manufacturer's name
top soil					0	3	Certainteed
•						Type	
redish brown clay				3	6	Set between <u>80</u> ft. and <u>100</u> ft.	
white clay				6	8	ft. and ft. Gravel pack? Size range of material \frac{1}{23/4}, \frac{3/8}{8}	
sand & gravel				8	12	11. Static water level: mo./day/yr. 50 ft. below land surface Date 11-11-75	
brown x clay				12	28	12. Pumping level below land surfaces: na	
sand & gravel				28	42	ft. afterhrs. pumping g.p.mft. afterhrs. pumping g.p.m.	
<u> </u>							Estimated maximum yieldg.p.m.
fine sand w/ clay and gravel mixed					42	90	13. Water sample submitted: mo./day/yr.
sand & gravel w/clay				90	100	Yes X No Date 14. Well head completion:	
brown & white clay				100	101	Pitless adapter Inches above grade	
							15. Well grouted?
hard red clay				101	110	Depth: From ft. to ft.	
							16. Nearest source of possible contamination:
							ft. 200 Direction West Type OilWell Well disinfected upon completion? X Yes No
					-		17 Pump Not installed
							Manufacturer's name
							Model number HP Volts
							Length of drop pipe ft. capacityg.p.m. Type:
							Submersible Turbine
	(Use a second s	heet if needed)					Jet Reciprocating Other
18. Elevation: 19. Remarks:							20. Water well contractor's certification:
8. Elevation: 1							This well was drilled under my jurisdiction and this report
8. Elevation: 1							
							is true to the best of my knowledge and belief.
							Rosencrantz-Bemis 134
Topography:							Rosencrantz-Bemis 134