


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Pratt	Fraction SE 1/4 SE 1/4 NE 1/4	Section number 36	Township number T 27 S	Range number R 13 E
2. Distance and direction from nearest town or city: 2 miles East of Pratt, KS Street address of well location if in city:			3. Owner of well: John Dauner R.R. or street: Star Route City, state, zip code: Pratt, KS 67124		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			6. Bore hole dia. 5 in. Completion date 7-12-77 Well depth 102 ft.		
			7. Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other <input type="checkbox"/>		
			9. Casing: Material Galv. Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP 2 PVC <input type="checkbox"/> Weight 84 lbs./ft. Dia. 2 in. to 84 ft. depth Wall thickness inches or Dia. 2 in. to 92 ft. depth gage No. 180#		
			10. Screen: Manufacturer's name Peerless Plastics Type PVC 160 Dia. 2" Slot gauze 1/8 Length 10' Set between 92 ft. and 102 ft. ft. and 102 ft. Gravel pack? yes Size range of material 3/8-200		
			11. Static water level: 65 ft. below land surface Date 7-12-77 mo./day/yr.		
			12. Pumping level below land surfaces: N/C ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
			14. Well head completion: Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: Field ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: Not installed Manufacturer's name Clayton Mark & Co. Model number 450 HP --- Volts --- Length of drop pipe 84' ft. capacity g.p.m. Type: 2" x 10" brass cylinder <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input checked="" type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			(Use a second sheet if needed)		
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					
		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name License No. Address Great Bend, KS 67530 Signed [Signature] Date 7-15-77 Authorized representative			

27 130 36 SE SE SE SE
1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5