


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pratt	Fraction 1/4 NW 1/4 NW 1/4	Section number 1	Township number T 27 S R 14 E	Range number 14 E
2. Distance and direction from nearest town or city: 3 1/2 miles West of Iuka, KS Street address of well location if in city:			3. Owner of well: Dale G. Mott R.R. or street: (?) City, state, zip code: Iuka, KS 67066			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		6. Bore hole dia. 24 in. Completion date 9-13-76 Well depth 169 ft.	
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
sandy top soil & yellow clay			0	32	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
fine sand			32	33	9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30.3 lbs./ft.	
hard brown clay			33	36	Wall Thickness: inches or Dia. 16 in. to 102 ft. depth gage No. 7 ga.	
soft brown clay			36	41	10. Screen: Manufacturer's name Doerr	
sand & gravel & thick clay streaks			41	48	Type double-slot Dia. 16" Slot gauge 1/8" Length 67' Set between 102 ft. and 169 ft. ft. and ft. Gravel pack? yes Size range of material 3/8-200	
sand & gravel			48	73	11. Static water level: mo./day/yr. 40 ft. below land surface Date 9-8-76	
white & brown clay			73	97	12. Pumping level below land surfaces: N/C ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
sand clay			97	99	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date	
white clay			99	102	14. Well head completion: Pitless adapter 12 Inches above grade	
sand & gravel & thin clay streaks			102	132	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
hard white clay			132	134	16. Nearest source of possible contamination: ft. Direction Type NONE KNOWN	
soft clay			134	135	Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
hard white clay			135	137	17. Pump: Not installed Manufacturer's name Peerless/FMC Corp Model number 12LB-3 HP 80 Volts --- Length of drop pipe 100 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
sand & gravel			137	143	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Equip. Inc. 185 Business name Great Bend, KS 66730 License No. Address 9-15-76 Signed [Signature] Date 9-15-76 Authorized representative	
soft sandy clay with sand streaks			143	156		
sand & gravel (Use a second sheet if needed)			156	168		
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5