USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section number		Township number Range number			
1. Location of well:	Pratt	Center	1/4	6		T 27 S R 1.		₽(W)	
2. Distance and direction from nearest town or city: 5\frac{1}{2}\text{ miles North of Cullison, KS} Street address of well location if in city:					er of well: Great M Plains Cattle Co. street: c/o Kenneth Maechtlen Box 2281 ote, zip code: Wichita, KS 67201				
4. Locate with "X" in section below: N						6. Bore hole dia. <u>24</u> in. Well depth <u>190</u> ft.	Completion date	1 <u>2–8–</u> 77	
NW	 NE					7 Cable tool Rotary Hollow rod Jetted	Driven Dug		
						8. Use: Domestic Public supply Industry X Irrigation Air conditioning Stock Lawn Oil field water Other			
						9. Casing: MaterialStee_Height Above r below Threaded Welded XSurface 12in. RMP PVC Weight 30 . 3lbs./ft.			
S 11 Mile						Dia. 16 in. to 60 ft. depth Wall Thickness: inches or Dia. 16 in. to 70 ft. depth gage No. 7 ga.			
5. Type and color of material				From	То	10. Screen: Manufacturer's name <u>Doerr</u>			
Sandy top soil				0	5	Double-slot		·	
Sandy brown & gray clay				5	57	Slot/gauze 1/8 Set between 60	ft and 110	ft.	
Sand & gravel				57	65	180 ft. a Gravel pack? Yes Size rar	nd <u>190</u>	ft. /8–200	
Brown & yellow clay				65		11. Static water level: mo./day/yr. 32 ft. below land surface Date 11-8-77			
Sand & gravel				68	9 8	12. Pumping level below land surfaces: N/C ft. after hrs. pumping g.p.m.			
Brown clay & limestone				98	105	ft. after hrs. pumping g.p.m.			
Sand & gravel				105	118	13. Water sample submitted:	mo	g.p.m.	
Brown & white clay with limestone streaks				118	173	14. Well head completion:	Date		
Sand & gravel & cemented gravel 93' to 190'				173	190	Pitlari adentes 12 Inches chave grade			
						With: X Neat cement Depth: From ft. to _	Bentonite 10 ft.	Concrete	10
						16. Nearest source of possible ft Direction		IELD	
						Well disinfected upon completed 17. Pump:	tion? Yes Not installed	<u>X</u> No	1
						Manufacturer's name Berk Model number 1202H-4	eley Pump		H
						Length of drop pipe 80	_ ft. capacity 900	Og.p.m. (Ę
						Type: Submersible	<u>X</u> Turbin	e	
(Use a second sheet if needed)						Jet Centrifugal	Recipr	ocating S	0
18. Elevation:	19. Remarks:					20. Water well contractor's co		s report	١٥
Topography:						is true to the best of my knowledge and belief.			
—— Hill						Clarke Well & E	Lic	185 A	\ (
Slope Upland						Address Great Bend	Le Dot	30 \\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\\	, v
Valley						Authorized repr	esentative	4	10