


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

**WATER WELL RECORD**  
**KSA 82a-1201-1215**

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

County <b>Pratt</b>		Fraction <b>1/4 1/4 CSE 1/4</b>		Section number <b>X 6</b>		Township number <b>T 27 S</b>		Range number <b>R 14 E W</b>																										
1. Location of well: <b>5 1/2 mi. North of Cullison, KS</b> Street address of well location if in city:				3. Owner of well: <b>N. L. Swinson</b> R.R. or street: <b>8130 E. Skelly Dr.</b> City, state, zip code: <b>Tulsa, OK 74129</b>																														
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E S 1 Mile</div> 				Sketch map:		6. Bore hole dia. <b>24</b> in. Completion date <b>10-13-75</b> Well depth <b>127</b> ft.																												
<table border="1"><thead><tr><th>5. Type and color of material</th><th>From</th><th>To</th></tr></thead><tbody><tr><td>Sandy top soil</td><td>0</td><td>4</td></tr><tr><td>Sand &amp; sandy clay</td><td>4</td><td>40</td></tr><tr><td>Sand, soft sandstone &amp; clay streaks</td><td>40</td><td>51</td></tr><tr><td>Sand &amp; gravel</td><td>51</td><td>107</td></tr><tr><td>Yellow clay &amp; limestone</td><td>107</td><td>110</td></tr><tr><td>Sand &amp; gravel</td><td>110</td><td>125</td></tr><tr><td>Gray clay</td><td>125</td><td>127</td></tr><tr><td colspan="3">(Use a second sheet if needed)</td></tr></tbody></table>				5. Type and color of material	From	To	Sandy top soil	0	4	Sand & sandy clay	4	40	Sand, soft sandstone & clay streaks	40	51	Sand & gravel	51	107	Yellow clay & limestone	107	110	Sand & gravel	110	125	Gray clay	125	127	(Use a second sheet if needed)			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
				5. Type and color of material	From	To																												
				Sandy top soil	0	4																												
				Sand & sandy clay	4	40																												
				Sand, soft sandstone & clay streaks	40	51																												
				Sand & gravel	51	107																												
				Yellow clay & limestone	107	110																												
				Sand & gravel	110	125																												
				Gray clay	125	127																												
				(Use a second sheet if needed)																														
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																																		
9. Casing: Material <b>Steel</b> Height <b>Above</b> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>30.3</b> lbs./ft. Dia. <b>16</b> in. to <b>67</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>7 ga.</b>																																		
10. Screen: Manufacturer's name <b>W. A. Brown</b> Type <b>Double-slot</b> Dia. <b>16"</b> <b>Slot</b> gauze <b>1/8</b> Length <b>60'</b> Set between <b>67</b> ft. and <b>127</b> ft. ft. and ft. Gravel pack? <b>Yes</b> Size range of material <b>3/8-200</b>																																		
11. Static water level: <input type="checkbox"/> mo./day/yr. <b>26</b> ft. below land surface Date <b>10-13-75</b>																																		
12. Pumping level below land surfaces: <b>N/C</b> ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.																																		
13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date																																		
14. Well head completion: Pitless adapter <b>12</b> inches above grade																																		
15. Well grouted? <b>Yes</b> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.																																		
16. Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No																																		
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																																		
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Clarke Well &amp; Eq., Inc.</b> <b>185</b> Business name License No. Address <b>Great Bend, KS</b> Signed <b>[Signature]</b> Date <b>10-13-75</b> Authorized representative																														

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5