


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Pratt	Fraction Center of 1/4 1/4 SE 1/4	Section number 8	Township number T 27 S R 14 E	Range number 14
2. Distance and direction from nearest town or city: 6 1/2 miles Northeast of Cullison, KS Street address of well location if in city:		3. Owner of well: Lincoln Land Co. R.R. or street: c/o Kenneth Maechtlen City, state, zip code: Box 2281 Wichita, KS 67201			
4. Locate with "X" in section below: Sketch map: 		6. Bore hole dia. 24 in. Completion date 11-17-77 Well depth 184 ft.			
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Top soil		0	4	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Sandy clay with fine sand		4	53	9. Casing: Material steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30.3 lbs./ft. Dia. 16 in. to 96 ft. depth Wall Thickness: inches or Dia. 16 in. to 164 ft. depth gage No. 7 ga.	
Sand & gravel & clay streak at 55'		53	80	10. Screen: Manufacturer's name Doerr Type Double-slot Dia. 16" Slot gauze 1/8" Length 60' Set between 96 ft. and 136 ft. 164 ft. and 184 ft. Gravel pack? Yes Size range of material 3/8-200	
Brown & gray clay & limestone		80	95	11. Static water level: 33 ft. below land surface Date 11-17-77	
Sand & gravel & clay streak at 100' to 103'		95	132	12. Pumping level below land surfaces Not Checked ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
Gray & white clay & limestone		132	163	13. Water sample submitted: ____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date ____	
Sand & gravel		163	184	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade	
(Use a second sheet if needed)				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: Field ft. ____ Direction ____ Type ____ Well disinfected upon completion? Yes <input type="checkbox"/> No <input checked="" type="checkbox"/>	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: Topography: ____ Hill ____ Slope ____ Upland ____ Valley	19. Remarks: This report is late due to waiting for pump to be set and one was not.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name License No. ____ Address Great Bend, KS 67530 Signed [Signature] Date 6-14-78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5