

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County: Pratt	Fraction: N 1/4 SE 1/4 SW 1/4	Section number: 4	Township number: T 27 S	Range number: R 15 W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Clarence Newby R.R. or street: Cullison Kansas City, state, zip code:			
4. Locate with "X" in section below:			Sketch map:		6. Bore hole dia. 8 1/2 in. Completion date 3-2-76 Well depth 100 ft.	
			Sandy Pasture		7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material			From	To	9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input checked="" type="checkbox"/> Welded <input type="checkbox"/> Surface 16 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 100 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. #200	
Top Blow Sand			0	3	10. Screen: Manufacturer's name Jess & Howell Type RMP Dia. 5" Slot/gauge 8 Length 20' Set between 80 ft. and 100 ft. ft. and ft. Gravel pack? No Size range of material	
Clay - DK Br.			3	10	11. Static water level: <input type="checkbox"/> mo./day/yr. 26 ft. below land surface Date 3-2-76	
Clay - Sandy Gray			10	18	12. Pumping level below land surfaces: 26 ft. after 1 hrs. pumping 3 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 25 g.p.m.	
Clay - Sandy Lt. BR.			18	62	13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date	
Gravel - 1/8 to 3/4			62	100	14. Well head completion: <input type="checkbox"/> Pitless adapter 16 inches above grade	
					15. Well grouted? YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 1 ft. to 11 ft.	
					16. Nearest source of possible contamination: ft. Direction Pasture Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Windmill Model number HP Volts Length of drop pipe 00 ft. capacity 3 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input checked="" type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Location is sand hill pasture.		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Carl Hayse Water Well Serv. 224 Business name License No. Address 603 S. Maple Greensboro, NC Signed Carl Hayse Date 3-2-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5