


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County PRATT	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 5	Township number T 27 S	Range number R 15 W E/W
2. Distance and direction from nearest town or city: 6N 4W 3/4 N of Cullison, Ks.			3. Owner of well: HAROLD SMITH R.R. or street: City, state, zip code: MACKSVILLE, Ks		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 		
5. Type and color of material			6. Bore hole dia. 30 in. Completion date 8 Sept 78 Well depth 135 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material STEEL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 95 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
			10. Screen: Manufacturer's name W.A. Brown Type <input type="checkbox"/> Dia. 16 in. Slot/gauze 1/8 Length 40 ft. Set between 95 ft. and 135 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 X 3/4		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 23 ft. below land surface Date 8 Sept 78		
			12. Pumping level below land surfaces: 33 ft. after 1 hrs. pumping 800 g.p.m. 36 ft. after 1 hrs. pumping 1000 g.p.m. Estimated maximum yield 1800 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: NONE ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: Manufacturer's name Simmons Not installed Model number <input type="checkbox"/> HP 60 Volts <input type="checkbox"/> Length of drop pipe 80 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			19. Remarks: 5' X 12.5' Concrete Slab was poured at surface		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump 325 Business name 121 S. Taylor Pratt Ks Address Bohonovich License No. 26 Sept 78 Signed Bohonovich Date 26 Sept 78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5