


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Pratt</b>	Township name <b>McClellan</b>	Fraction <b>CSE 1/4</b>	Section number <b>15</b>	Town number <b>T27S</b>	Range number <b>R15W</b> <del>XXX R15W</del>
Distance and direction from nearest town or city: <b>6 mi. Northwest of Cullison, KS</b> Street address of well location if in city:				3 Owner of well: <b>Jack Spines</b> Address: <b>Wichita, KS</b>		
Locate with "X" in section below: N  W S 1 Mile				Sketch map:		
2				4 Well depth: <b>190</b> ft. Date of completion <b>3-20-75</b> Well diameter <b>24</b> in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Top soil & fill				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
Sandy clay & soft sandstone				7 Casing: Material <b>Steel</b> Height: <b>above</b> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. <b>16</b> in. to <b>80</b> ft. depth Weight <b>30.3</b> lbs./ft. <b>16</b> in. to <b>170</b> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
sand & gravel				8 Screen: Manufacturer <b>W. A. Brown</b> Type <b>Double-slot</b> Dia. <b>16"</b> Slot gauge <b>1/8</b> Length <b>80'</b> Set between <b>80</b> ft. and <b>140</b> ft. Fittings: <b>170' &amp; 190'</b> 3/8200 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material		
Soft brown clay & gravel				9 Static water level: <b>36 1/2</b> ft. below land surface Date <b>3-20-75</b>		
Sand & gravel				10 Pumping level below land surfaces: <b>N/C</b> ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.		
Pink clay & limestone				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Sand & gravel				12 Well head completion: <b>XXX 12</b> <input type="checkbox"/> Pitless adapter <b>XXX</b> inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite Depth: From <b>0</b> ft. to <b>10</b> ft.		
				14 Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(use a second sheet if needed)						
16 Remarks: elevation  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Clarke Well &amp; Eq., Inc.</b> 185 Business name License No. Address <b>Great Bend, KS</b> Signed <b>D. W. Clarke</b> Date <b>3-20-75</b> Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5