

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County Pratt	Township name McClellan	Fraction SW $\frac{1}{4}$ of SE $\frac{1}{4}$	Section number 21	Town number T27S	Range number R15W
Distance and direction from nearest town or city: 6 $\frac{1}{2}$ mi. Northwest of Cullison, KS Street address of well location if in city:			3 Owner of well: Thad Robbins Address: Wichita, Kansas			
Locate with "X" in section below: N W E S 1 Mile			Sketch map: 4 Well depth: 160 ft. Date of completion 3-17-75 Well diameter 24 in. 5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> 7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. Weight 30.3 lbs./ft. 16 in. to 80 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth			
2 Type and color of material			From	To	8 Screen: Manufacturer W. A. Brown Type Double-slot Dia. 16" Slot gauge 1/8 Length 80' Set between 80 ft. and 160 ft. Fittings: 3/8-200 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material	
Sandy top soil			0	4	9 Static water level: 48 ft. below land surface Date 3-17-75	
Brown clay			4	68	10 Pumping level below land surfaces: N/C ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
Sand, gravel & thin clay streaks at 106'			68	122	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
Brown & gray clay			122	126	12 Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade	
Sand & gravel			126	142	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.	
Gray clay & limestone			142	145	14 Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Sand & gravel			145	160	15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(use a second sheet if needed)						
16 Remarks: elevation  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name License No. Address Great Bend, KS Signed Date 3-17-75 Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5