


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Pratt</b>	Township name <b>McClellan</b>	Fraction <b>CSE 1/4</b>	Section number <b>23</b>	Town number <b>T27S</b>	Range number <b>R15W</b>
Distance and direction from nearest town or city: <b>3 1/2 mi. Northwest of Cullison, KS</b> Street address of well location if in city:			3 Owner of well: <b>Ivan Stotts</b> Address: <b>Byers, Kansas</b>			
Locate with "X" in section below: N  W S 1 Mile E			Sketch map:			4 Well depth: <b>160</b> ft. Date of completion <b>3-25-75</b> Well diameter <b>24</b> in.
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
Top soil & sand			0	8	6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
Brown & gray clay & sandstreaks			8	68	7 Casing: Material <b>Steel</b> Height: <b>above</b> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. <b>16</b> in. to <b>100</b> ft. depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight <b>30.3</b> lbs./ft. <b>16</b> in. to <b>100</b> ft. depth!	
Sand & sandy clay			68	97	8 Screen: <b>W. A. Brown</b> -- Db1 -- slot Manufacturer <b>XXXXXXXXXXXX</b> Type <b>XXXXXXXXXX</b> Dia. <b>16"</b> Slot gauge <b>1/8</b> Length <b>60'</b> Set between <b>100</b> ft. and <b>160</b> ft. Fittings: <b>3/8-200</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material	
Sand & gravel			97	160	9 Static water level: <b>45</b> ft. below land surface Date <b>3-25-75</b>	
					10 Pumping level below land surfaces: <b>N/C</b> ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
					12 Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <b>0</b> ft. to <b>XXX</b> ft. <b>10</b>	
					14 Nearest source of possible contamination: fr. ____ Direction ____ Type ____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
16 Remarks: elevation  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Clarke Well &amp; Eq., Inc.</b> <b>185</b> Business name <b>Great Bend, KS</b> License No. <b>3-25-75</b> Address <b>3-25-75</b> Signed <b>Authorized representative</b> Date			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5