


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Platt	Fraction C/S W 1/4 1/4 1/4	Section number 25	Township number 27	Range number 15	E/W
2. Distance and direction from nearest town or city: 3 1/2 W 7 1/2 S of Cullison, Ks Street address of well location if in city:				3. Owner of well: Charles Grisby R.R. or street: City, state, zip code: Cullison, Ks			
4. Locate with "X" in section below: N 1 Mile W E S 1 Mile				Sketch map: 			
5. Type and color of material				From	To	6. Bore hole dia. 2 1/2 in. Completion date 4-12-76 Well depth 149 ft.	
Sandy Top Soil				0	5	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
DARK Brown Clay				5	16	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Redish Clay				16	51	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 1 1/2 in. to 1 1/2 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 7	
Sand and Gravel				51	57	10. Screen: Manufacturer's name Doerrs Type steel Dia. 1 1/2 Slot size 3/16 Length 48 Set between 101 ft. and 148 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 3/8	
Redish Clay				57	61	11. Static water level: <input type="checkbox"/> mo./day/yr. 61 ft. below land surface Date 2-19-76	
Sand & Gravel				61	122	12. Pumping level below land surfaces: 58 ft. after 1 hrs. pumping 1400 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1400+ g.p.m.	
Gray Clay				122	123	13. Water sample submitted: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 4-3-5-76	
Sand and Gravel				123	138	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
Sand & Gravel with Clay				138	148	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
Redish Clay				148	150	16. Nearest source of possible contamination: ft. 5m Direction NW Type septic tank Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
						17. Pump: Not installed Manufacturer's name W-L-B Model number 4-CH-12 HP 80 Volts <input type="checkbox"/> Length of drop pipe 100 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)							
18. Elevation:		19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosenkrantz - Bemis 134 Business name Creat Bend, Ks License No. <input type="checkbox"/> Address Medea Bend Date 9/27/76 Signed Medea Bend Authorized representative					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5