

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County PRATT	Fraction NW 1/4 SW 1/4 SW 1/4	Section number 28	Township number T 27 S R 15 W	Range number E/W
2. Distance and direction from nearest town or city: 4W & 2 1/2 N			3. Owner of well: KANSAS FORESTRY FISH & GAME			
Street address of well location if in city: of Cullison, KS			City, state, zip code: Pratt, KS			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 30 in. Completion date 11 Jan 78		
				Well depth 160 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other		
				9. Casing: Material PTL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 2.5 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 13.77 lbs./ft. Dia. 12 in. to 120 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 330		
5. Type and color of material				From	To	10. Screen: Manufacturer's name Coak
Soil				0	2	Type wire wound Dia. 13"
Clay, Brown & Gray				2	48	Slot/gauze 100 Length 40'
Sand, Very fine to Coarse				48	67	Set between 120 ft. and 160 ft.
Sand, fine to Coarse & fine to med gravel				67	75	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 x 1/2
Sand, fine to Coarse & med to very Coarse gravel				75	114	11. Static water level: 48 ft. below land surface Date 11 Jan 78
Clay, sandy tan				114	117	12. Pumping level below land surfaces: 56 ft. after 4 hrs. pumping 500 g.p.m. 61 ft. after 4 hrs. pumping 750 g.p.m. Estimated maximum yield 1200 g.p.m.
Sand, fine to Coarse & fine to very Coarse gravel				117	132	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 11 Jan 78
Clay, tan				132	135	14. Well head completion: <input type="checkbox"/> Pitless adapter 2.5' Inches above grade
Sand, fine to Coarse & med to very Coarse gravel				135	159	15. Well grouted? <input checked="" type="checkbox"/> X
Clay, tan				159	163	With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Sand, very fine to Coarse & fine gravel				163	186	16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type none
Sandy fine to Coarse & fine to Coarse gravel				186	197	Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Sand, fine to Coarse & med to very Coarse gravel				197	215	17. Pump: <input type="checkbox"/> Not installed
Shale, black				215	220	Manufacturer's name SIMMONS
						Model number <input type="checkbox"/> HP 20 Volts 460
						Length of drop pipe 80 ft. capacity 700 g.p.m.
						Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine
						<input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating
						<input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		6'x6'x6" slab was poured at surface		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump 325 Business name 131 S Topeka License No. Pratt Address Pratt, KS Signed Thomson Date 22 July 78 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5