


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County <u>Pratt</u>	Fraction <u>CNE</u> 1/4 1/4 1/4	Section number <u>34</u>	Township number <u>27</u> T S R	Range number <u>15</u> E/W
2. Distance and direction from nearest town or city: <u>1 n 2 1/2 mi 1/4 n Collinson</u> Street address of well location if in city:			3. Owner of well: <u>Floyd Rose</u> R.R. or street: <u>18626 Northridge Drive</u> City, state, zip code: <u>Salinas, Calif</u>			
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 		6. Bore hole dia. <u>2 1/2</u> in. Completion date <u>1-20-75</u> Well depth <u>212</u> ft.	
5. Type and color of material			From To		7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Sandy Top Soil			0 2		9. Casing: Material <u>Steel</u> Height <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>15</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. <u>1 1/2</u> in. to <u>2 1/2</u> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>7</u>	
					10. Screen: Manufacturer's name <u>Dacelis</u> Type <u>steel</u> Dia. <u>1 1/2</u> Slot <u>3/16</u> Length <u>80</u> Set between <u>103</u> ft. and <u>123</u> ft. <u>143</u> ft. and <u>183</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>12 3/4 20</u>	
Sandy Brown Clay			2 23		11. Static water level: <u>65</u> ft. below land surface Date <u>7-25-74</u> mo./day/yr.	
Gray Clay			23 28		12. Pumping level below land surfaces: <u>58</u> ft. after <u>1</u> hrs. pumping <u>1000</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>1200</u> g.p.m.	
Sandy Brown & Gray Clay			28 32		13. Water sample submitted: <u> </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u> </u>	
Tough Brown Clay			32 70		14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
Sandy Brown & white Clay			70 95		15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.	
Sand & Gravel clean coarse loose			95 104		16. Nearest source of possible contamination: ft. <u>34</u> Direction <u>North</u> Type <u>Corral</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
Brown Clay			104 106		17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Fairbanks Morse</u> Model number <u>3A12</u> HP <u>100</u> Volts <u> </u> Length of drop pipe <u>120</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Sand & Gravel clean coarse loose			106 123		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Rosenkrantz - Bemis</u> <u>134</u> Business name License No. Address <u>Great Bend, Ks.</u> Signed <u>Richard Anderson</u> Date <u>9/20/74</u> Authorized representative	
Sandy Brown & white Clay streaks			123 148		1/4 1/4 1/4 CNE	
Sand & Gravel clean coarse loose			148 183			
Brown Clay			183 196			
Sand & Gravel little Clay			196 199			
Brown Clay			199 201		1/4 1/4 1/4	
Sand & Gravel loose coarse sand			201 213		1/4 1/4 1/4	
Brown Clay			213 223		1/4 1/4 1/4	
18. Elevation: <u>Gray Clay</u> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: <u>223/225</u> (use a second sheet if needed)				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5