

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction 1/4 c 1/4 sec 1/4	Section number 6	Township number T 27 S R 16 E	Range number 16 E
2. Distance and direction from nearest town or city: 6-3/4-N of Haviland, Ks. west side Street address of well location if in city:				3. Owner of well: Gerald Tuttle R.R. or street: none City, state, zip code: Haviland, Kansas 67059		
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 29 in. Completion date _____ Well depth 177 ft. 2-13-75	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Low <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
sandy top soil		0	2	9. Casing: Material steel Height: Above or below _____ Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. 16 in. to 177 ft. depth Wall thickness: inches or _____ Dia. _____ in. to _____ ft. depth gage No. 7		
brown sandy clay		2	4	10. Screen: Manufacturer's name _____ Doerrs Type steel Dia. _____ Slot xxx 3/16 Length 60 Set between 117 ft. and 177 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8		
fine sand		4	11	11. Static water level: _____ mo./day/yr. 16 ft. below land surface Date 12-3-74		
sandy brown gray clay & fine sand		11	27	12. Pumping level below land surfaces: 32 ft. after 1 hrs. pumping 800 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1600 g.p.m.		
sand & gravel clean coarse loose		27	47	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 12-3-74		
sandy brown clay		47	53	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
sand & gravel clean coarse loose		53	75	15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
brown clay		75	88	16. Nearest source of possible contamination: ft. 5/8 mi. Direction south Type gaswell Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
sand & gravel clean coarse loose		88	98	17. Pump: _____ Nat installed Manufacturer's name W.L.R. Model number 5-12CHC HP 80 Volts _____ Length of drop pipe 70 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
brown clay w/sand		126	132	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Kansas 67530 Signed S. Kilgore Date 6-19-74 Authorized representative		
sand & gravel clean coarse loose		132	177			
light gray white clay		177	180			
yellow brown light gray clay		180	187			
18. Elevation:	19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

27-1600-06-1/4-1/4-SE

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5