

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County KIOWA	Fracton NW 1/4 SE 1/4 SE 1/4	Section number 7	Township number T 27	Range number S R 16W E/W
2. Distance and direction from nearest town or city: 6 N of Haviland, Ks			3. Owner of well: LARRY SNEED			
Street address of well location if in city:			R.R. or street:			
City, state, zip code: HAVILAND, Ks						
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 30 in. Completion date 29 Dec 78 Well depth 148 ft.	
					7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Soil, SANDY		0	3	9. Casing: Material STL Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 16 in. to 108 ft. depth Well Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
Clay, gray & blue		3	11	10. Screen: Manufacturer's name WA Brown Type <input type="checkbox"/> Dia. 16" Slot/gauze 1/8 Length 40' Set between 108 ft. and 148 ft. ft. and <input type="checkbox"/> ft.		
Sand, fine & Tan clay		11	27	Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/8 x 3/8		
Sand, fine to coarse & coarse gravel		27	86	11. Static water level: <input type="checkbox"/> mo./day/yr. 22 ft. below land surface Date 29 Dec 78		
Clay, Tan		86	108	12. Pumping level below land surfaces: 34 ft. after 1 hrs. pumping 800 g.p.m. 39 ft. after 1 hrs. pumping 1000 g.p.m. Estimated maximum yield 2000 g.p.m.		
Sand, fine to coarse & very coarse gravel		108	120	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
Clay, Tan		120	125	14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
Sand, fine to coarse & very coarse gravel		125	152	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: NONE ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name SIMMONS Model number <input type="checkbox"/> HP 80 Volts <input type="checkbox"/> Length of drop pipe 80 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:	19. Remarks: 9' x 13' x 8" concrete slab poured at surface			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Central Well & Pump 328 Business name Dex 1032 Pratt Ks License No. <input type="checkbox"/> Address Pittsboro Signed Pittsboro Date 15 Jan 79 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

27
 16W
 Sec 7
 NW SE SE
 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5