

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Kiowa	Fraction NW 1/4 1/4 1/4	Section number 9	Township number T 27 S R 16 E/W	Range number
2. Distance and direction from nearest town or city: 7 mi. North 1 East of Haviland Street address of well location if in city:			3. Owner of well: Glenn Shriver R.R. or street: Coats, Kansas City, state, zip code:			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <u>30</u> in. Completion date _____ Well depth <u>172</u> ft. <u>5/6/77</u>		
		Well No. 3 (TH 1-75)		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material <u>Stl.</u> Height: Above <u>below</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>34.25</u> lbs./ft. Dia. <u>16</u> in. to <u>105</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>203</u> "		
Sandy soil		0	2	10. Screen: Manufacturer's name <u>Doerr</u> <u>Metal Products</u> Type <u>S. Steel</u> Dia. <u>16</u> " Slot/gauze <u>1/8</u> Length <u>68</u> " Set between <u>82</u> ft. and <u>94</u> ft. <u>116</u> ft. and <u>172</u> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <u>1/2 x 3/8</u> "		
Fine sand		2	15	11. Static water level: _____ mo./day/yr. <u>22</u> ft. below land surface Date <u>5/6/77</u>		
Sandy clay		15	20	12. Pumping level below land surfaces: <u>51</u> ft. after <u>4</u> hrs. pumping <u>1002</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
Brown clay		20	35	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
Med. to co. sand & gravel		35	75	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade		
Gray clay		75	80	15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.		
Med. to co. sand & gravel		80	95	16. Nearest source of possible contamination: ft. <u>2500</u> Direction <u>NW</u> Type <u>Farm</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Tan clay		95	116	17. Pump: _____ Not installed Manufacturer's name <u>Layne & Bowler</u> Model number <u>12 KMH</u> HP <u>100</u> Volts _____ Length of drop pipe <u>100</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Med. to co. sand & gravel		116	127	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name _____ License No. _____ Address <u>Wichita, Kansas</u> Signed <u>[Signature]</u> Date <u>5/11/77</u> Authorized representative		
Tan clay w/sand lenses		127	130			
Med. to co. sand & gravel		130	141			
Tan clay w/sand & gravel		141	147			
Med. to coarse sand & gravel		147	158			
Gray clay		158	160	18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		
Med. to co. sand & gravel		160	172			
Gray clay		172	175			
19. Remarks: (Use a second sheet if needed)						

97
 16
 9
 6
 NW
 1/4 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5