

WATER WELL RECORD Form WWC-5 KSA 82a-1212

1 LOCATION OF WATER WELL: Fraction Section Number Township Number Range Number  
 COUNTY: 049 KIOWA SW 1/4 SW 1/4 SE 1/4 17 T 27 S R 16 N

Distance and direction from nearest town or city street address of well if located within city?  
 5 N. 1/2 E. OF HAVILAND, KS

2 WATER WELL OWNER: KEITH HINGSHAW 258 Board of Agriculture, Division of Water Resources  
 RR#, St. Address, Box #: R.R.1, BOX 26  
 City, State, ZIP code: HAVILAND, KS 67059- Application Number:

3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL 140 ELEVATION:																											
<table border="1"> <tr> <td>1</td> <td>---</td> <td>NW</td> <td>---</td> <td>NE</td> <td>---</td> </tr> <tr> <td>1</td> <td>W</td> <td></td> <td>E</td> <td></td> </tr> <tr> <td>1</td> <td></td> <td>SW</td> <td></td> <td>SE</td> </tr> <tr> <td>1</td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td>1</td> <td></td> <td></td> <td></td> <td></td> </tr> </table>		1	---	NW	---	NE	---	1	W		E		1		SW		SE	1					1					Depth(s) Groundwater Encountered 1. 45 ft. 2. ft. 3. ft.	
		1	---	NW	---	NE	---																						
		1	W		E																								
		1		SW		SE																							
		1																											
1																													
WELL'S STATIC WATER LEVEL 45 ft. below land surface measured on mo/day/yr		Pump test data: Well water was ft. after hours pumping gpm																											
Estimated Yield gpm: Well water was ft. after hours pumping gpm		Bore Hole Diameter 8.75 in. to 140 ft., and in. to ft.																											
WELL WATER TO BE USED AS: 01 DOMESTIC		Was a chemical/bacteriological sample submitted to department? No ;																											
		If yes, mo/day/yr sample was submitted Water well disinfected? Yes																											

5 TYPE OF BLANK CASING USED: 02 PVC CASING JOINTS: GLUED  
 Blank casing diameter 5 in. to 120 ft., Dia in. to ft., Dia in. to ft.  
 Casing height above land surface 12 in., weight lbs/ft. Wall thickness or gauge No. 26  
 TYPE OF SCREEN OR PERFORATION MATERIAL: 07 PVC  
 SCREEN OR PERFORATION OPENINGS ARE: 08 SAW CUT

SCREEN PERFORATED INTERVALS: From 120 ft. to 140 ft., From ft. to ft.  
 From ft. to ft., From ft. to ft.  
 GRAVEL PACK INTERVALS: From 25 ft. to 140 ft., From ft. to ft.  
 From ft. to ft., From ft. to ft.

6 GROUT MATERIAL 03 BENTONITE  
 Grout Intervals: From 3 ft. to 25 ft., From ft. to ft., From ft. to ft.  
 What is the nearest source of possible contamination: 01 SEPTIC TANK  
 Direction from well? S.E. How many feet? 100

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
	6	SILT & SAND			
6	11	GREY CLAY			
11	28	TAN CLAY			
28	104	05 SAND AND 17 GRAVEL			
104	121	TAN CLAY			
121	140	05 SAND AND 17 GRAVEL			

7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 3 /3 /94 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 224 This Water Well Record was completed on (mo/day/yr) 03/29/94 under the business name of CARL HAYSE WATER WELL SVC by (signature) Carl Hayse